

LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
(AUGUST 2015)

LOCATION (BIÑAN CITY)		Date of Sampling	Time of Sampling	Heterotrophic	Coliform Bacteria ²	Residual
				Plate Count ¹ (CFU/mL)		Chlorine ³ (mg/L)*
1	Adelina Deepwell	8/5/2015	10:03 AM	<1	ABSENT	0.63
2	Adelina Block 2 Lot 1	8/5/2015	10:15 AM	-	ABSENT	<0.30
3	Source, Almeda	8/26/2015	1:25 PM	<1	ABSENT	<0.30
4	Brgy. Hall, Dela Paz	8/26/2015	1:31 PM	-	ABSENT	<0.30
5	Source, Malaban Faraon	8/26/2015	11:36 AM	<1	ABSENT	<0.30
6	Block 5 Lot 12, Margarita Homes	8/26/2015	11:13 AM	-	ABSENT	<0.30
7	Source, Southville Langkiwa	8/19/2015	10:50 AM	<1	ABSENT	<0.30
8	Block 3, Phase 2, Southville Langkiwa	8/19/2015	11:07 AM	-	ABSENT	<0.30
9	Tank, Metroville, Brgy. Canlalay	8/19/2015	12:51 PM	<1	ABSENT	<0.30
10	Clubhouse, Metroville	8/19/2015	1:04 PM	-	ABSENT	<0.30
11	Source, Phase 1B Olivarez Subdivision	8/5/2015	11:15 AM	<1	ABSENT	<0.30
12	Block 1 Lot 26, Olivarez Phase 3	8/5/2015	10:57 AM	-	ABSENT	<0.30
13	Block 1 Lot 16, Olivarez Phase 4	8/5/2015	10:30 AM	<1	ABSENT	<0.30
14	Block 2 Lot 9, Olivarez Phase 4	8/5/2015	10:41 AM	-	ABSENT	<0.30
15	Brgy. Hall Poblacion, Brgy. Poblacion, City of Biñan	8/26/2015	1:03 PM	<1	ABSENT	<0.30
16	#84A, Bonifacio St., Brgy. Canlalay	8/26/2015	1:47 PM	-	ABSENT	<0.30
17	Tangub St., Pragmatic	8/5/2015	9:21 AM	<1	ABSENT	0.60
18	Bais Street, Pragmatic	8/5/2015	9:36 AM	-	ABSENT	0.42
19	#407, San Vicente	8/5/2015	9:18 AM	<1	ABSENT	0.87
20	B12 L5, Bayabas St. Olivarez 7, San Vicente	8/5/2015	11:33 AM	-	ABSENT	0.63
21	#21, Soro-Soro	8/5/2015	12:14 PM	<1	ABSENT	<0.30
22	#76, Soro-Soro	8/5/2015	12:03 PM	-	ABSENT	<0.30
23	South Plains II Deepwell	8/5/2015	8:57 AM	<1	ABSENT	0.31
24	Block 11 Lot 6, South Plains II	8/5/2015	8:50 AM	-	ABSENT	0.31
25	Southville Town & Country Amsterdam Deepwell	8/19/2015	11:41 AM	<1	ABSENT	<0.30
26	Southville Town & Country Block 35 Lot 21-Amsterdam	8/19/2015	11:50 AM	-	ABSENT	<0.30
27	Southville Town & Country Pennsylvania Deepwell	8/19/2015	12:09 PM	<1	ABSENT	0.83
28	Southville Town & Country Block 2 Lot 5	8/19/2015	12:17 PM	-	ABSENT	0.78
29	Source 1, Verdana Subdivision	8/19/2015	9:57 AM	<1	ABSENT	<0.30
30	Block 5 Lot 16, Brgy. Malamig	8/19/2015	10:15 AM	-	ABSENT	<0.30
31	Verdana Clubhouse	8/19/2015	9:43 AM	-	ABSENT	0.32
32	Drinking Fountain, Ganado Elementary School	8/19/2015	1:55 PM	-	ABSENT	0.32
33	Drinking Fountain 1, Malaban Faraon Elem. School	8/26/2015	11:58 AM	-	ABSENT	<0.30
34	Drinking Fountain 2, Malaban Faraon Elem. School	8/26/2015	12:04 PM	-	ABSENT	<0.30
35	Drinking Fountain, Southville Langkiwa Elem. School	8/19/2015	11:14 AM	-	ABSENT	<0.30
36	Drinking Fountain, St. Michael School of Biñan	8/5/2015	8:51 AM	-	ABSENT	<0.30
37	Brgy. Platero	8/5/2015	9:04 AM	-	ABSENT	<0.30
PNSDW LIMIT				<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method

Legend: *Detection Limit = <0.3 mg/L

Prepared by:

Certified Correct:



CYRIL A. ERICA, RMT

Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)




AMPARO C. CAÑAMO
Head of the Laboratory

LOCATION		Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
(SANTA ROSA CITY)						
1	Alinsod Deepwell	8/26/2015	2:29 PM	<1	ABSENT	0.91
2	#152, Purok 1, Alinsod	8/26/2015	2:34 PM	-	ABSENT	0.61
3	Cobassuisse Deepwell	8/25/2015	1:07 PM	<1	ABSENT	<0.30
4	Cobassuisse Block 5 Lot 25	8/25/2015	1:18 PM	-	ABSENT	<0.30
5	Golden City Ph 1E/3E Deepwell	8/25/2015	9:59 AM	<1	ABSENT	0.41
6	Golden City Ph 1E/3E Block 6 Lot 6	8/25/2015	10:11 AM	-	ABSENT	<0.30
7	Golden City Ph 2E Deepwell	8/25/2015	9:13 AM	<1	ABSENT	<0.30
8	Golden City Ph 2E Block 13 Lot 5	8/25/2015	8:52 AM	-	ABSENT	<0.30
9	Laguna Bel-Air 1 Block 7 Deepwell	8/4/2015	10:16 AM	<1	ABSENT	<0.30
10	Laguna Bel-Air 1 Block 7 Lot 74	8/4/2015	10:20 AM	-	ABSENT	<0.30
11	Laguna Bel-Air 1 Block 34 Deepwell	8/4/2015	10:02 AM	<1	ABSENT	<0.30
12	Laguna Bel-Air 1 Block 34 Lot 59	8/4/2015	10:10 AM	-	ABSENT	<0.30
13	Laguna Bel-Air 1 Block 62 - Clubhouse	8/4/2015	10:56 AM	-	ABSENT	<0.30
14	Laguna Bel-Air 2 Block 71 Deepwell	8/4/2015	11:32 AM	<1	ABSENT	<0.30
15	Laguna Bel-Air 2 Block 71 Lot 4	8/4/2015	12:08 PM	-	ABSENT	2.90
16	Laguna Bel-Air 2 Block 108 Deepwell	8/4/2015	11:44 AM	<1	ABSENT	0.49
17	Laguna Bel-Air 2 Block 108 - Church	8/4/2015	11:51 AM	-	ABSENT	0.39
18	Laguna Bel-Air 3 Block 2 Deepwell	8/4/2015	8:51 AM	<1	ABSENT	<0.30
19	Laguna Bel-Air 3 Block 2 (Hillcrest Road)	8/4/2015	9:02 AM	-	ABSENT	<0.30
20	Laguna Bel-Air 3 Block 8	8/4/2015	9:31 AM	<1	ABSENT	<0.30
21	Laguna Bel-Air 3 Block 8 Brenna Model House	8/4/2015	9:42 AM	-	ABSENT	<0.30
22	Laguna Bel-Air 3 Block 50 Deepwell	8/4/2015	9:12 AM	<1	ABSENT	<0.30
23	Laguna Bel-Air 3 - Clubhouse	8/4/2015	9:21 AM	-	ABSENT	<0.30
24	Laguna Bel-Air 4 Block 43 Deepwell	8/4/2015	10:32 AM	<1	ABSENT	<0.30
25	Laguna Bel-Air 4 Block 47 Lot 12	8/4/2015	10:42 AM	-	ABSENT	<0.30
26	Source, Market Area	8/26/2015	10:43 AM	<1	ABSENT	0.62
27	Block 9 Lot 2, Terry Town West, Market Area	8/26/2015	9:19 AM	-	ABSENT	0.40
28	Metrogate, Tank	8/26/2015	8:01 AM	<1	ABSENT	1.12
29	Rosa Subd. Brgy. Macablang, Metrogate	8/26/2015	6:41 AM	-	ABSENT	1.18
30	Block 24 Lot 12, New Santa Rosa Homes (near DW)	8/12/2015	9:06 AM	<1	ABSENT	0.30
31	Block 21 Lot 43, New Santa Rosa Homes	8/12/2015	9:14 AM	-	ABSENT	<0.30
32	Source, Brgy. Pulong Santa Cruz	8/27/2015	9:30 AM	<1	ABSENT	1.10
33	Purok 5, Sitio Arattan, Brgy. Pulong Santa Cruz	8/27/2015	9:45 AM	-	ABSENT	0.93
34	Source, Rosewood	8/5/2015	8:19 AM	<1	ABSENT	0.44
35	Block 7 Lot 26, Rosewood	8/5/2015	8:30 AM	-	ABSENT	0.42
36	San Lorenzo Royale Deepwell	8/11/2015	11:53 AM	<1	ABSENT	<0.30
37	Block 11 Lot 52, San Lorenzo Royale	8/11/2015	12:01 PM	-	ABSENT	<0.30
38	Purok 2 near Deepwell, Sinalhan	8/26/2015	10:03 AM	<1	ABSENT	<0.30
39	Purok 4, Sinalhan	8/26/2015	10:25 AM	-	ABSENT	<0.30
40	Sol-Car Deepwell	8/12/2015	8:40 AM	<1	ABSENT	0.75
41	Elevated Tank, Sol-Car	8/12/2015	8:45 AM	-	ABSENT	0.66
42	Deepwell 1, Santa Rosa Village I	8/26/2015	7:22 PM	<1	ABSENT	1.89
43	Clubhouse, Santa Rosa Village I	8/26/2015	7:33 PM	-	ABSENT	<0.30
44	Deepwell 6, Phase 4C, San Jose Village I	8/26/2015	6:33 PM	<1	ABSENT	0.82
45	Deepwell 2, San Jose Village I - Phase 3B	8/26/2015	6:54 PM	<1	ABSENT	0.73
46	Clubhouse, San Jose Village I - Phase 3B	8/26/2015	7:03 PM	-	ABSENT	0.73
47	Clubhouse, San Jose Village I - Phase 4C	8/26/2015	6:41 PM	-	ABSENT	0.68
48	Deepwell 11, San Jose Village II - Phase V	8/26/2015	6:08 PM	-	ABSENT	<0.30
49	Clubhouse, San Jose Village II - Phase V	8/26/2015	6:17 PM	-	ABSENT	<0.30
50	Deepwell 7, San Jose Village III - Phase VI	8/26/2015	5:55 PM	<1	ABSENT	0.47
51	Clubhouse, San Jose Village III - Phase VI	8/26/2015	5:45 PM	-	ABSENT	0.45
52	Booster Tank, Santa Rosa Estates	8/26/2015	4:48 PM	<1	ABSENT	0.52
53	Clubhouse, Santa Rosa Village II	8/26/2015	5:20 PM	-	ABSENT	<0.30
54	Clubhouse, Santa Rosa Estates I	8/26/2015	5:02 PM	-	ABSENT	<0.30
55	Clubhouse, Santa Rosa Estates II	8/26/2015	8:00 PM	-	ABSENT	<0.30
56	Southville Caingin Phase 1, Block 57	8/11/2015	9:56 AM	<1	ABSENT	<0.30
57	Southville Caingin Phase 1, Block 28 Lot 2	8/11/2015	10:15 AM	-	ABSENT	0.88
58	Southville Caingin Phase 5, Source	8/11/2015	10:48 AM	<1	ABSENT	<0.30
59	Southville Caingin Phase 5, Block 17 Lot 12	8/11/2015	10:38 AM	-	ABSENT	<0.30
60	Tank, South Hampton	8/26/2015	10:15 AM	<1	ABSENT	<0.30
61	Clubhouse, South Hampton	8/26/2015	10:26 AM	-	ABSENT	<0.30
62	Terra Fortuna Deepwell	8/11/2015	11:18 AM	<1	ABSENT	0.61
63	Block 11 Lot 16, Terra Fortuna	8/11/2015	11:25 AM	-	ABSENT	0.57
64	Villa Esmeralda Deepwell	8/11/2015	11:35 AM	<1	ABSENT	0.30
65	Villa Esmeralda Block (Alabaster St.)	8/11/2015	11:40 AM	-	ABSENT	0.30
66	Villa Las Casas Deepwell	8/25/2015	12:41 PM	<1	ABSENT	<0.30
67	Villa Las Casas Block 1 Lot 14	8/25/2015	12:52 PM	-	ABSENT	<0.30
68	Reservoir, Mesaland	8/25/2015	10:39 AM	<1	ABSENT	1.23
69	Block 6 Lot 8 Buklod Diwa	8/25/2015	11:00 AM	<1	ABSENT	1.14
70	Bakery, Brgy. Malusak	8/26/2015	8:19 AM	-	ABSENT	1.11
71	Block 11 Lot 2, JB Village, Brgy. Balibago	8/25/2015	2:57 PM	-	ABSENT	1.49
72	#1780, Brgy. Dita	8/18/2015	1:40 PM	-	ABSENT	0.65
73	#31 J. P. Rizal Blvd., Tagapo	8/19/2015	1:31 PM	-	ABSENT	0.41
74	Laguna AAWater Corporation	8/12/2015	2:20 PM	-	ABSENT	1.20
75	Drinking Fountain, Front Gate, Central 1 Elem. Sch.	8/26/2015	8:57 AM	-	ABSENT	0.58
76	Drinking Fountain, Roberto Gonzales Bldg. 1, Central 1 Elementary School	8/26/2015	8:45 AM	-	ABSENT	1.19
77	Drinking Fountain, Roberto Gonzales Bldg. 2, Central 1 Elementary School	8/26/2015	8:35 AM	-	ABSENT	0.64
78	Drinking Fountain, Caingin Elementary School	8/4/2015	2:04 PM	-	ABSENT	<0.30
79	Drinking Fountain, Dila Elementary School	8/11/2015	3:41 PM	-	ABSENT	<0.30
PNSDW LIMIT				<500	ABSENT	


Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method

Legend: *Detection Limit <0.3 mg/L

Prepared by:


CYRLA A. BRICA, RMT
Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:


AMPARO C. CAÑAMO
Head of the Laboratory

LOCATION (CABUYAO CITY)	Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
1 Cabuyao Central Deepwell	8/25/2015	10:46 AM	<1	ABSENT	<0.30
2 Cabuyao Central Clubhouse	8/25/2015	10:59 AM	-	ABSENT	0.61
3 Block 3 Lot 17, Celestine Phase 1	8/12/2015	1:07 PM	<1	ABSENT	<0.30
4 Block 26 Lot 4, Celestine Phase 1	8/12/2015	1:47 PM	-	ABSENT	<0.30
5 Source, Celestine Phase 2	8/12/2015	1:39 PM	<1	ABSENT	<0.30
6 Celestine Phase 2 Block 11 Lot 19	8/12/2015	1:33 PM	-	ABSENT	<0.30
7 Celestine Ville Deepwell	8/18/2015	12:56 AM	<1	ABSENT	<0.30
8 Guardhouse, Celestine Ville	8/18/2015	1:11 PM	-	ABSENT	<0.30
9 Mabuhay Phase 1 Block 101 Deepwell	8/18/2015	11:53 AM	<1	ABSENT	0.36
10 Mabuhay Phase 1 Block 95 Lot 57	8/18/2015	12:12 PM	-	ABSENT	<0.30
11 Mabuhay Phase 2 Block 141 Deepwell	8/18/2015	12:31 PM	<1	ABSENT	<0.30
12 Mabuhay Phase 2 Block 4 Lot 20	8/18/2015	12:43 PM	-	ABSENT	<0.30
13 Mabuhay Phase 2 Block 198 Deepwell	8/18/2015	11:26 AM	<1	ABSENT	<0.30
14 Mabuhay Phase 2 Block 222 Lot 20	8/18/2015	11:40 AM	-	ABSENT	<0.30
15 Mabuhay Phase 3 Cluster Deepwell	8/18/2015	9:51 AM	<1	ABSENT	<0.30
16 Mabuhay Phase 3 Cluster Block 1 Lot 17	8/18/2015	10:05 AM	-	ABSENT	<0.30
17 Mabuhay Phase 3 Luxury Deepwell	8/18/2015	10:32 AM	<1	ABSENT	<0.30
18 Mabuhay Phase 3 Luxury Block 19 Lot 13	8/18/2015	10:18 AM	-	ABSENT	<0.30
19 Mabuhay Phase 5 Deepwell	8/18/2015	9:09 AM	<1	ABSENT	<0.30
20 Mabuhay Phase 5 Block 31 Lot 134	8/18/2015	9:28 AM	-	ABSENT	<0.30
21 Source, Multi-Land III	8/12/2015	9:59 AM	<1	ABSENT	0.34
22 Guardhouse, Multi-Land Block III	8/12/2015	10:10 AM	-	ABSENT	<0.30
23 Multi-Land IV Deepwell	8/18/2015	10:58 AM	<1	ABSENT	<0.30
24 Multi-Land IV Block 3 Lot 33	8/18/2015	11:07 AM	-	ABSENT	<0.30
25 Source, Niugan	8/25/2015	11:44 AM	<1	ABSENT	0.35
26 Block 5 Lot 12, St. Francis, Niugan	8/25/2015	12:03 PM	-	ABSENT	<0.30
27 Southville Tank 1 Blk 25 Deepwell	8/12/2015	12:50 PM	<1	ABSENT	0.37
28 Southville Tank 1 Blk 19 Lot 33	8/12/2015	11:42 AM	-	ABSENT	0.36
29 Southville Tank 4 Blk 45 Deepwell	8/12/2015	11:14 AM	<1	ABSENT	0.35
30 Southville Tank 4 Blk 40 Lot 132	8/12/2015	11:28 AM	-	ABSENT	0.77
31 Southville Tank 5 Blk 54 Deepwell	8/12/2015	10:55 AM	<1	ABSENT	<0.30
32 Southville Tank 5 Blk 47 Lot 101	8/12/2015	11:04 AM	-	ABSENT	<0.30
33 Willow Park, Tank	8/25/2015	11:16 AM	<1	ABSENT	<0.30
34 Guardhouse, Willow Park	8/25/2015	11:25 AM	-	ABSENT	<0.30
35 Matang Tubig Spring, Brgy. Casile, Cabuyao City	8/25/2015	10:21 AM	<1	ABSENT	1.24
36 #253 Elsol Subdivision, Cabuyao City	8/12/2015	9:43 AM	-	ABSENT	0.73
37 Drinking Fountain, Niugan Elementary School	8/12/2015	10:34 AM	-	ABSENT	<0.30
PNSDW LIMIT			<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method

Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT

Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
(AUGUST 2015)

LOCATION (SANTA CRUZ CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
1	Source	8/27/2015	10:15 AM	<1	ABSENT	0.52
2	Canteen	8/27/2015	10:30 AM	-	ABSENT	0.40
PNSDW LIMIT				<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method

Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT

Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 534 1627 · (02) 519 4887