

LOCATION		Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*	
Sampling Point	Barangay						
1	Adelina Deepwell	Brgy. Sto. Tomas, Biñan	11/17/2015	9:18 AM	84	ABSENT	<0.30
2	Gate Entrance, Adelina	Brgy. Sto. Tomas, Biñan	11/17/2015	9:29 AM	-	ABSENT	0.41
3	Source, Almeda	Brgy. Dela Paz, Biñan	11/23/2015	1:15 PM	120	ABSENT	<0.30
4	Brgy. Hall	Brgy. Dela Paz, Biñan	11/23/2015	1:40 PM	-	ABSENT	<0.30
5	Source, Malaban Faraon	Brgy. San Antonio, Biñan	11/23/2015	1:42 PM	99	ABSENT	<0.30
6	Block 5 Lot 12, Margarita Homes	Brgy. San Antonio, Biñan	11/23/2015	12:25 PM	-	ABSENT	<0.30
7	Source, Southville Langkiwa	Brgy. Langkiwa, Biñan	11/9/2015	11:51 AM	<1	ABSENT	<0.30
8	Block 40, Phase 20, Southville Langkiwa	Brgy. Langkiwa, Biñan	11/9/2015	12:05 PM	-	ABSENT	<0.30
9	Tank, Metroville	Brgy. Canlalay, Biñan	11/10/2015	9:35 AM	<1	ABSENT	0.78
10	Clubhouse, Metroville	Brgy. Halang, Biñan	11/10/2015	9:48 AM	-	ABSENT	0.98
11	Source, Phase 1B Olivarez Subdivision	Brgy. Sto. Tomas, Biñan	11/17/2015	9:03 AM	<1	ABSENT	0.52
12	Block 1 Lot 26, Olivarez Phase 3	Brgy. Sto. Tomas, Biñan	11/17/2015	8:45 AM	-	ABSENT	1.56
13	Block 1 Lot 16, Olivarez Phase 4	Brgy. Sto. Tomas, Biñan	11/17/2015	8:23 AM	<1	ABSENT	1.59
14	Block 2 Lot 9, Olivarez Phase 4	Brgy. Sto. Tomas, Biñan	11/17/2015	8:33 AM	-	ABSENT	1.91
15	Brgy. Hall - Poblacion	Brgy. Poblacion, Biñan	11/23/2015	2:03 PM	84	ABSENT	<0.30
16	#84A, Bonifacio St.	Brgy. Canlalay, Biñan	11/23/2015	10:32 AM	-	ABSENT	<0.30
17	Golden City Canlalay - Clubhouse	Brgy. Canlalay, Biñan	11/10/2015	9:01 AM	-	ABSENT	0.59
18	Tangub St., Pragmatic	Brgy. Sto. Tomas, Biñan	11/3/2015	10:20 AM	<1	ABSENT	0.77
19	Bais St., Pragmatic	Brgy. Sto. Tomas, Biñan	11/3/2015	9:38 AM	-	ABSENT	0.74
20	#407, San Vicente	Brgy. San Vicente, Biñan	11/3/2015	8:32 AM	<1	ABSENT	1.34
21	B12 L5, Bayabas St. Olivarez 7	Brgy. San Vicente, Biñan	11/3/2015	8:46 AM	-	ABSENT	0.75
22	#21, Soro-Soro	Brgy. Soro-soro, Biñan	11/10/2015	10:25 AM	96	ABSENT	<0.30
23	#76, Soro-Soro	Brgy. Soro-soro, Biñan	11/10/2015	10:10 AM	-	ABSENT	<0.30
24	South Plains II Deepwell	Brgy. Sto. Tomas, Biñan	11/3/2015	10:38 AM	<1	ABSENT	0.59
25	Block 11 Lot 6, South Plains II	Brgy. Sto. Tomas, Biñan	11/3/2015	10:47 AM	-	ABSENT	0.61
26	Southville Town & Country Amsterdam Deepwell	Brgy. Sto. Tomas, Biñan	11/17/2015	10:03 AM	<1	ABSENT	0.34
27	Southville Town & Country Block 35 Lot 21-Amsterdam	Brgy. Sto. Tomas, Biñan	11/17/2015	10:24 AM	-	ABSENT	0.51
28	Southville Town & Country Pennsylvania Deepwell	Brgy. Sto. Tomas, Biñan	11/9/2015	12:37 PM	<1	ABSENT	1.46
29	Southville Town & Country Block 2 Lot 5	Brgy. Sto. Tomas, Biñan	11/9/2015	12:48 PM	-	ABSENT	1.28
30	Source 1, Verdana Subdivision	Brgy. Mamlasan, Biñan	11/9/2015	1:20 PM	<1	ABSENT	1.12
31	Block 5, Lot 16	Brgy. Malamig, Biñan	11/9/2015	1:57 PM	-	ABSENT	0.72
32	Verdana Clubhouse	Brgy. Mamlasan, Biñan	11/9/2015	1:08 PM	-	ABSENT	0.67
33	Drinking Fountain, Dela Paz Elementary School	Brgy. Dela Paz, Biñan	11/10/2015	9:18 AM	3	ABSENT	<0.30
34	Drinking Fountain, Ganado Elementary School	Brgy. Mamlasan, Biñan	11/3/2015	11:25 AM	-	ABSENT	<0.30
35	Drinking Fountain, Loma Elementary School	Brgy. Malamig, Biñan	11/9/2015	12:30 OM	-	ABSENT	<0.30
36	Drinking Fountain 1, Malaban Faraon Elem. School	Brgy. San Antonio, Biñan	11/23/2015	12:47 PM	-	ABSENT	<0.30
37	Drinking Fountain 2, Malaban Faraon Elem. School	Brgy. San Antonio, Biñan	11/23/2015	12:57 PM	-	ABSENT	<0.30
38	Drinking Fountain, St. Michael School of Biñan	Brgy. Platero, Biñan	11/10/2015	8:33 AM	1	ABSENT	0.75
39	Brgy. Hall - Platero	Brgy. Platero, Biñan	11/10/2015	8:44 AM	-	ABSENT	0.82
PNSDW LIMIT					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method

Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT
Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
(NOVEMBER 2015)

LOCATION (SANTA ROSA CITY)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
#	Sampling Point	Barangay					
1	Alinsod Deepwell	Brgy. Pooc, Sta. Rosa	11/18/2015	8:22 AM	<1	ABSENT	0.38
2	#152, Purok 1, Alinsod	Brgy. Pooc, Sta. Rosa	11/18/2015	8:38 AM	-	ABSENT	0.39
3	Cobassuise Deepwell	Brgy. Malitlit, Sta. Rosa	11/18/2015	11:04 AM	<1	ABSENT	1.66
4	Cobassuise Block 5 Lot 25	Brgy. Malitlit, Sta. Rosa	11/18/2015	11:12 AM	-	ABSENT	1.71
5	Golden City Ph 1E/3E Deepwell	Brgy. Dila, Sta. Rosa	11/4/2015	10:26 AM	<1	ABSENT	0.70
6	Golden City Ph 1E/3E Block 6 Lot 6	Brgy. Dila, Sta. Rosa	11/4/2015	10:37 AM	-	ABSENT	<0.30
7	Golden City Ph 2E Deepwell	Brgy. Dila, Sta. Rosa	11/4/2015	10:40 AM	<1	ABSENT	<0.30
8	Golden City Ph 2E Block 13 Lot 5	Brgy. Dila, Sta. Rosa	11/4/2015	10:49 AM	-	ABSENT	<0.30
9	Laguna Bel-Air 1 Block 7 Deepwell	Brgy. Don Jose, Sta. Rosa	11/23/2015	10:03 AM	<1	ABSENT	<0.30
10	Laguna Bel-Air 1 Block 7 Lot 74	Brgy. Don Jose, Sta. Rosa	11/23/2015	10:12 AM	-	ABSENT	<0.30
11	Laguna Bel-Air 1 Block 34 Deepwell	Brgy. Don Jose, Sta. Rosa	11/9/2015	1:32 PM	<1	ABSENT	0.49
12	Laguna Bel-Air 1 Block 34 Lot 59	Brgy. Don Jose, Sta. Rosa	11/9/2015	1:55 PM	-	ABSENT	0.48
13	Laguna Bel-Air 2 Block 71 Deepwell	Brgy. Don Jose, Sta. Rosa	11/16/2015	12:06 PM	<1	ABSENT	0.43
14	Laguna Bel-Air 2 Block 71 Lot 4	Brgy. Don Jose, Sta. Rosa	11/16/2015	12:16 PM	-	ABSENT	0.38
15	Laguna Bel-Air 2 Block 108 Deepwell	Brgy. Don Jose, Sta. Rosa	11/23/2015	9:32 AM	<1	ABSENT	0.30
16	Laguna Bel-Air 2 Block 108 - Church	Brgy. Don Jose, Sta. Rosa	11/23/2015	9:42 AM	-	ABSENT	<0.30
17	Laguna Bel-Air 3 Block 2 Deepwell	Brgy. Loma, Sta. Rosa	11/9/2015	11:41 AM	<1	ABSENT	0.57
18	Laguna Bel-Air 3 Block 2 (Hillcrest Road)	Brgy. Loma, Sta. Rosa	11/9/2015	12:30 PM	-	ABSENT	0.69
19	Laguna Bel-Air 3 Block 8	Brgy. Loma, Sta. Rosa	11/9/2015	12:00 AM	<1	ABSENT	<0.30
20	Laguna Bel-Air 3 Block 8 Brenna Model House	Brgy. Loma, Sta. Rosa	11/9/2015	1:17 PM	-	ABSENT	<0.30
21	Laguna Bel-Air 3 Block 50 Deepwell	Brgy. Loma, Sta. Rosa	11/9/2015	12:41 PM	<1	ABSENT	0.60
22	Laguna Bel-Air 3 - Clubhouse	Brgy. Loma, Sta. Rosa	11/9/2015	12:53 PM	-	ABSENT	<0.30
23	Laguna Bel-Air 4 Block 43 Deepwell	Brgy. Don Jose, Sta. Rosa	11/23/2015	10:26 AM	<1	ABSENT	<0.30
24	Laguna Bel-Air 4 Block 47 Lot 12	Brgy. Don Jose, Sta. Rosa	11/23/2015	10:36 AM	-	ABSENT	<0.30
25	Source, Market Area	Brgy. Balibago, Sta. Rosa	11/11/2015	10:11 AM	<1	ABSENT	0.80
26	Block 9 Lot 2, Terry Town West, Market Area	Brgy. Balibago, Sta. Rosa	11/11/2015	10:34 AM	-	ABSENT	0.81
27	Metrogate, Tank	Brgy. Tagapo, Sta. Rosa	11/18/2015	12:51 PM	<1	ABSENT	1.47
28	Rosa Subd., Metrogate	Brgy. Macablang, Sta. Rosa	11/18/2015	8:38 AM	-	ABSENT	1.06
29	Near Tank, New Santa Rosa Homes (near DW)	Brgy. Dita, Sta. Rosa	11/4/2015	9:15 AM	<1	ABSENT	<0.30
30	Block 24 Lot 12, New Santa Rosa Homes	Brgy. Dita, Sta. Rosa	11/4/2015	9:01 AM	-	ABSENT	<0.30
31	Source, Pulong Santa Cruz	Brgy. Pulong Sta. Cruz, Sta. Rosa	11/16/2015	11:50 AM	<1	ABSENT	0.40
32	Purok 5, Sitio Arattan	Brgy. Pulong Sta. Cruz, Sta. Rosa	11/16/2015	11:36 AM	-	ABSENT	0.33
33	Source, Rosewood	Brgy. Halang, Sta. Rosa	11/3/2015	9:40 AM	<1	ABSENT	0.70
34	Block 7 Lot 26, Rosewood	Brgy. Halang, Sta. Rosa	11/3/2015	9:58 AM	-	ABSENT	0.65
35	San Lorenzo Royale Deepwell	Brgy. Dita, Sta. Rosa	11/16/2015	11:18 AM	<1	ABSENT	<0.30
36	Block 11 Lot 52, San Lorenzo Royale	Brgy. Dita, Sta. Rosa	11/16/2015	11:08 AM	-	ABSENT	<0.30
37	Purok 2 near Deepwell, Sinalhan	Brgy. Sinalhan, Sta. Rosa	11/11/2015	9:46 AM	<1	ABSENT	<0.30
38	Purok 4, Sinalhan	Brgy. Sinalhan, Sta. Rosa	11/11/2015	9:27 AM	-	ABSENT	<0.30
39	Sol-Car Deepwell	Brgy. Dita, Sta. Rosa	11/18/2015	9:05 AM	<1	ABSENT	0.46
40	Elevated Tank, Sol-Car	Brgy. Dita, Sta. Rosa	11/18/2015	8:54 AM	-	ABSENT	0.45
41	Deepwell 1, Santa Rosa Village I	Brgy. Don Jose, Sta. Rosa	11/16/2015	11:44 AM	<1	ABSENT	0.48
42	Clubhouse, Santa Rosa Village I	Brgy. Don Jose, Sta. Rosa	11/16/2015	11:53 AM	-	ABSENT	<0.30
43	Deepwell 6, Phase 4C, San Jose Village I	Brgy. Don Jose, Sta. Rosa	11/16/2015	1:16 PM	<1	ABSENT	0.34
44	Deepwell 2, San Jose Village I - Phase 3B	Brgy. Don Jose, Sta. Rosa	11/16/2015	12:10 PM	<1	ABSENT	0.99
45	Clubhouse, San Jose Village I - Phase 3B	Brgy. Don Jose, Sta. Rosa	11/16/2015	12:19 PM	-	ABSENT	1.04
46	Clubhouse., San Jose Village I - Phase 4C	Brgy. Don Jose, Sta. Rosa	11/16/2015	1:25 PM	-	ABSENT	0.36
47	Deepwell 11, San Jose Village II - Phase V	Brgy. Don Jose, Sta. Rosa	11/16/2015	12:53 AM	<1	ABSENT	0.29
48	Clubhouse, San Jose Village II - Phase V	Brgy. Don Jose, Sta. Rosa	11/16/2015	1:03 PM	-	ABSENT	0.48
49	Deepwell 7, San Jose Village III - Phase VI	Brgy. Don Jose, Sta. Rosa	11/16/2015	12:31 PM	<1	ABSENT	1.46
50	Clubhouse, San Jose Village III - Phase VI	Brgy. Don Jose, Sta. Rosa	11/16/2015	12:41 PM	-	ABSENT	1.42
51	Booster Tank, Santa Rosa Estates	Brgy. Don Jose, Sta. Rosa	11/16/2015	10:39 AM	<1	ABSENT	<0.30
52	Clubhouse, Santa Rosa Village II	Brgy. Don Jose, Sta. Rosa	11/16/2015	11:28 AM	-	ABSENT	0.82
53	Clubhouse, Santa Rosa Estates I	Brgy. Don Jose, Sta. Rosa	11/16/2015	10:48 AM	-	ABSENT	0.57
54	Clubhouse, Santa Rosa Estates II	Brgy. Don Jose, Sta. Rosa	11/16/2015	11:05 AM	-	ABSENT	0.85
55	Southville Caingin Phase 1, Block 52 Lot 23	Brgy. Caingin, Sta. Rosa	11/3/2015	11:03 AM	<1	ABSENT	<0.30
56	Southville Caingin Phase 1, Block 57 Lot 17	Brgy. Caingin, Sta. Rosa	11/3/2015	11:18 AM	-	ABSENT	<0.30
57	Southville Caingin Phase 5, Block 1 Lot 34	Brgy. Pooc, Sta. Rosa	11/3/2015	11:47 AM	<1	ABSENT	<0.30
58	Southville Caingin Phase 2, Block 46 Lot 2	Brgy. Pooc, Sta. Rosa	11/3/2015	11:34 AM	-	ABSENT	3.68
59	Tank, South Hampton	Brgy. Balibago, Sta. Rosa	11/4/2015	11:04 AM	<1	ABSENT	0.46
60	Clubhouse, South Hampton	Brgy. Balibago, Sta. Rosa	11/4/2015	11:16 AM	-	ABSENT	<0.30

61	Terra Fortuna Deepwell	Brgy. Malitlit, Sta. Rosa	11/18/2015	11:58 AM	<1	ABSENT	1.23
62	Block 11 Lot 16, Terra Fortuna	Brgy. Malitlit, Sta. Rosa	11/18/2015	12:09 PM	-	ABSENT	1.22
63	Villa Esmeralda Deepwell	Brgy. Dita, Sta. Rosa	11/16/2015	10:42 AM	<1	ABSENT	0.91
64	Villa Esmeralda Block (Alabaster St.)	Brgy. Dita, Sta. Rosa	11/16/2015	10:54 AM	-	ABSENT	0.91
65	Villa Las Casas Deepwell	Brgy. Malitlit, Sta. Rosa	11/18/2015	11:23 AM	<1	ABSENT	0.94
66	Villa Las Casas Block 1 Lot 14	Brgy. Malitlit, Sta. Rosa	11/18/2015	11:41 AM	-	ABSENT	1.77
67	Reservoir, Mesaland	Brgy. Don Jose, Sta. Rosa	11/11/2015	9:55 AM	<1	ABSENT	1.36
68	Block 6 Lot 8 Buklod Diwa	Brgy. Pulong Sta. Cruz, Sta. Rosa	11/11/2015	9:28 AM	<1	ABSENT	1.16
69	Brgy. Hall - Malusak	Brgy. Malusak, Sta. Rosa	11/11/2015	11:32 AM	-	ABSENT	0.76
70	Block 11 Lot 2, JB Village	Brgy. Balibago, Sta. Rosa	11/18/2015	1:10 PM	-	ABSENT	0.84
71	#1780	Brgy. Dita, Sta. Rosa	11/18/2015	10:10 AM	-	ABSENT	0.38
72	#31 J. P. Rizal Blvd.	Brgy. Tagapo, Sta. Rosa	11/3/2015	10:09 AM	-	ABSENT	0.81
73	Laguna AAWater Corporation	Brgy. Balibago, Sta. Rosa	11/23/2015	11:46 AM	-	ABSENT	1.20
74	Drinking Fountain, Caingin Elementary School	Brgy. Caingin, Sta. Rosa	11/3/2015	10:46 AM	-	ABSENT	<0.30
75	Drinking Fountain, Front Gate, Central 1 Elem. Sch.	Brgy. Malusak, Sta. Rosa	11/11/2015	10:48 AM	-	ABSENT	0.71
76	Drinking Fountain, Roberto Gonzales Bldg. 1, Central 1 Elementary School	Brgy. Malusak, Sta. Rosa	11/11/2015	11:03 AM	-	ABSENT	0.83
77	Drinking Fountain, Roberto Gonzales Bldg. 2, Central 1 Elementary School	Brgy. Tagapo, Sta. Rosa	11/11/2015	10:57 AM	-	ABSENT	0.83
78	Drinking Fountain, Dila Elementary School	Brgy. Dila, Sta. Rosa	11/18/2015	10:26 AM	-	ABSENT	0.30
PNSDW LIMIT						<500	ABSENT

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT
Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AA WATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026


Telephone Number: (049) 534 1627 - (02) 519 4887

LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
(NOVEMBER 2015)


No.	LOCATION (CABUYAO CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
	Sampling Point	Barangay					
1	Cabuyao Central Deepwell	Brgy. Pulo, Cabuyao	11/10/2015	9:21 AM	5	ABSENT	<0.30
2	Cabuyao Central Clubhouse	Brgy. Pulo, Cabuyao	11/10/2015	9:37 AM	-	ABSENT	<0.30
3	Block 3 Lot 17, Celestine Phase 1	Brgy. Marinig, Cabuyao	11/11/2015	9:33 AM	<1	ABSENT	<0.30
4	Block 26 Lot 4, Celestine Phase 1	Brgy. Marinig, Cabuyao	11/11/2015	9:37 AM	-	ABSENT	<0.30
5	Source, Celestine Phase 2	Brgy. Marinig, Cabuyao	11/11/2015	10:07 AM	<1	ABSENT	<0.30
6	Celestine Phase 2 Block 11 Lot 19	Brgy. Marinig, Cabuyao	11/11/2015	10:20 AM	-	ABSENT	<0.30
7	Celestine Ville Deepwell	Brgy. Gulod, Cabuyao	11/4/2015	10:25 AM	<1	ABSENT	<0.30
8	Guardhouse, Celestine Ville	Brgy. Gulod, Cabuyao	11/4/2015	10:38 AM	-	ABSENT	<0.30
9	Mabuhay Phase 1 Block 101 Deepwell	Brgy. Mamatid, Cabuyao	11/4/2015	9:22 AM	<1	ABSENT	0.42
10	Mabuhay Phase 1 Block 95 Lot 57	Brgy. Mamatid, Cabuyao	11/4/2015	9:33 AM	-	ABSENT	0.47
11	Mabuhay Phase 2 Block 141 Deepwell	Brgy. Mamatid, Cabuyao	11/4/2015	9:46 AM	<1	ABSENT	0.57
12	Mabuhay Phase 2 Block 4 Lot 20	Brgy. Mamatid, Cabuyao	11/4/2015	10:10 AM	-	ABSENT	0.58
13	Mabuhay Phase 2 Block 198 Deepwell	Brgy. Mamatid, Cabuyao	11/4/2015	8:48 AM	<1	ABSENT	0.31
14	Mabuhay Phase 2 Block 222 Lot 20	Brgy. Mamatid, Cabuyao	11/4/2015	9:03 AM	-	ABSENT	0.46
15	Mabuhay Phase 3 Cluster Deepwell	Brgy. Mamatid, Cabuyao	11/17/2015	10:40 AM	<1	ABSENT	<0.30
16	Mabuhay Phase 3 Cluster Block 1 Lot 17	Brgy. Mamatid, Cabuyao	11/17/2015	10:29 AM	-	ABSENT	<0.30
17	Mabuhay Phase 3 Luxury Deepwell	Brgy. Mamatid, Cabuyao	11/17/2015	10:01 AM	<1	ABSENT	<0.30
18	Mabuhay Phase 3 Luxury Block 19 Lot 13	Brgy. Mamatid, Cabuyao	11/17/2015	10:16 AM	-	ABSENT	<0.30
19	Mabuhay Phase 5 Deepwell	Brgy. Mamatid, Cabuyao	11/17/2015	9:31 AM	<1	ABSENT	<0.30
20	Mabuhay Phase 5 Block 31 Lot 134	Brgy. Mamatid, Cabuyao	11/17/2015	9:45 AM	-	ABSENT	<0.30
21	Source, Multi-Land III	Brgy. Sala, Cabuyao	11/18/2015	9:39 AM	<1	ABSENT	0.65
22	Guardhouse, Multi-Land III	Brgy. Sala, Cabuyao	11/18/2015	9:50 AM	-	ABSENT	<0.30
23	Multi-Land IV Deepwell	Brgy. San Isidro, Cabuyao	11/17/2015	9:09 AM	<1	ABSENT	<0.30
24	Multi-Land IV Block 3 Lot 33	Brgy. San Isidro, Cabuyao	11/17/2015	8:58 AM	-	ABSENT	<0.30
25	Source, Niugan	Brgy. Niugan, Cabuyao	11/10/2015	11:10 AM	24	ABSENT	<0.30
26	Patricia's Apartment, Niugan	Brgy. Niugan, Cabuyao	11/10/2015	11:23 AM	-	ABSENT	<0.30
27	Southville Tank 1 Blk 25 Deepwell	Brgy. Marinig, Cabuyao	11/11/2015	10:36 AM	<1	ABSENT	0.60
28	Southville Tank 1 Blk 19 Lot 33	Brgy. Marinig, Cabuyao	11/11/2015	10:48 AM	-	ABSENT	0.63
29	Southville Tank 4 Blk 45 Deepwell	Brgy. Niugan, Cabuyao	11/11/2015	11:05 AM	<1	ABSENT	0.40
30	Southville Tank 4 Blk 40 Lot 132	Brgy. Niugan, Cabuyao	11/11/2015	11:18 AM	-	ABSENT	0.47
31	Southville Tank 5 Blk 54 Deepwell	Brgy. Niugan, Cabuyao	11/10/2015	10:31 AM	<1	ABSENT	0.77
32	Southville Tank 5 Blk 47 Lot 101	Brgy. Niugan, Cabuyao	11/10/2015	10:41 AM	-	ABSENT	0.48
33	Willow Park, Tank	Brgy. Pulo, Cabuyao	11/10/2015	9:56 AM	<1	ABSENT	<0.30
34	Guardhouse, Willow Park	Brgy. Pulo, Cabuyao	11/10/2015	10:10 AM	-	ABSENT	<0.30
35	Matang Tubig Spring	Brgy. Casile, Cabuyao	11/11/2015	10:56 AM	<1	ABSENT	1.03
36	#253 Elsol Subdivision, Cabuyao City	Brgy. Elsol, Cabuyao	11/18/2015	9:22 AM	-	ABSENT	0.43
37	Wash Area, Niugan Elementary School	Brgy. Niugan, Cabuyao	11/10/2015	11:04 AM	33	ABSENT	<0.30
PNSDW LIMIT					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
Legend: *Detection Limit = <0.3 mg/L

Prepared by:


CYRIL A. ERICA, RMT
 Analyst (PRC License No. 0054161)
 (NRL No. WLMA-14-0274)

Certified Correct:


AMPARO C. CAÑAMO
 Head of the Laboratory

LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
(NOVEMBER 2015)

LOCATION (CALAMBA CITY)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
#	Sampling Point	Address					
1	Deepwell 1, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	11/24/2015	10:40 AM	<1	ABSENT	0.96
2	Near Tank 1, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	11/24/2015	10:25 AM	-	ABSENT	0.54
3	Blow off 1, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	11/24/2015	12:13 PM	-	ABSENT	0.46
4	Deepwell 2, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	11/24/2015	10:58 AM	<1	ABSENT	0.83
5	Near Tank 2, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	11/24/2015	10:49 AM	-	ABSENT	0.59
6	Blow off 2, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	11/24/2015	11:21 AM	-	ABSENT	0.50
PNSDW LIMIT					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method

Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT

Analyst (PRC License No. 0054161)

(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO

Head of the Laboratory

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 534 1627 · (02) 519 4887




LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
 (NOVEMBER 2015)

LOCATION (SANTA CRUZ CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/ml)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*	
Sampling Point	Address						
1	Deepwell Source (after DMI 65)	San Luis Sports Complex, Sta. Cruz, Laguna	11/25/2015	1:26 PM	<1	ABSENT	0.80
2	Canteen No. 4 in front of the Laguna University Administration Bldg.	San Luis Sports Complex, Sta. Cruz, Laguna	11/25/2015	1:49 PM	-	ABSENT	0.40
PNSDW LIMIT					<500	ABSENT	


Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
 Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERIQA, RMT
 Analyst (PRC License No. 0054161)
 (NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
 Head of the Laboratory

LAGUNA AAAWATER CORPORATION
 A Joint Venture of the Provincial Government of Laguna and Manila Water Company
 2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026
 Telephone Number: (049) 534 1627 - (02) 519 4887