

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : BIÑAN	MONTH : APRIL	YEAR : 2016
---------------------------	---------------	-------------

NO	SAMPLE LOCATION		DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BIÑAN							
1	Laguna Well Field 1	Source	4/18/2016	2:30 PM	<1	ABSENCE	ABSENCE
2	Pump 6, Santol St., Phase 4C, San Jose Village I	Source	4/11/2016	12:03 PM	1	ABSENCE	ABSENCE
3	Blk 3 Lot 28, Santol st., Phase 4C, San Jose Village I	Distribution	4/11/2016	12:17 PM	16	ABSENCE	ABSENCE
4	Pump 2, Jacana St., Phase 3B, San Jose Village I	Source	4/11/2016	12:32 PM	<1	ABSENCE	ABSENCE
5	Blk 2 Lot 18, Jacana St., Phase 3B, San Jose Village I	Distribution	4/11/2016	1:04 PM	-	ABSENCE	ABSENCE
6	Pump 11, Phase 5, San Jose Village II	Source	4/11/2016	11:41 AM	<1	ABSENCE	ABSENCE
7	Blk 1 Lot 23, Camia St., Phase 5, San Jose Village II	Distribution	4/11/2016	11:26 AM	<1	ABSENCE	ABSENCE
8	Pump 7, Phase 6, San Jose Village III	Source	4/11/2016	10:52 AM	-	ABSENCE	ABSENCE
9	Block 14 Lot 3, Phase 6, San Jose Village III	Distribution	4/11/2016	11:08 AM	<1	ABSENCE	ABSENCE
BRGY. CANLALAY							
10	#84 A. Bonifacio St.	Distribution	4/26/2016	12:44 PM	-	ABSENCE	ABSENCE
11	Golden City Canlalay Clubhouse	Distribution	4/13/2016	10:17 AM	<1	ABSENCE	ABSENCE
12	Drinking Fountain, Canlalay Elementary School	Distribution	4/13/2016	10:27 AM	-	ABSENCE	ABSENCE
BRGY. DELA PAZ							
13	9028 WP GP Sta. Bernardina St. Kapitana Dela Paz	Source	4/26/2016	12:01 PM	<1	ABSENCE	ABSENCE
14	Barangay Hall	Distribution	4/26/2016	12:27 PM	-	ABSENCE	ABSENCE
BRGY. GANADO							
15	Drinking Fountain, Ganado Elementary School	Distribution	4/13/2016	12:27 PM	-	ABSENCE	ABSENCE
BRGY. HALANG							
16	9999 WP Metroville Complex	Source	4/13/2016	10:38 AM	-	ABSENCE	ABSENCE
17	Clubhouse, Metroville Complex	Distribution	4/13/2016	11:05 AM	<1	ABSENCE	ABSENCE
BRGY. LANGKIWA							
18	Block 3 Lot 9 Phase 2, Southville Langkiwa	Source	4/18/2016	12:41 PM	<1	ABSENCE	ABSENCE
19	Block 3 Lot 9, Phase 2, Southville Langkiwa	Distribution	4/18/2016	12:47 PM	-	ABSENCE	ABSENCE
20	Drinking Fountain, Langkiwa Elementary School	Distribution	4/18/2016	12:56 PM	-	ABSENCE	ABSENCE
BRGY. LOMA							
21	Block 2 Lot 16, Phase 1, Laguna Bel-Air 3	Source	4/6/2016	9:44 AM	1	ABSENCE	ABSENCE
22	Hillcrest Road, Block 2, Laguna Bel-Air 3	Distribution	4/6/2016	9:57 AM	393	ABSENCE	ABSENCE
23	4NR Block 99, Phase 4, Laguna Bel-Air 3	Source	4/6/2016	10:54 AM	-	ABSENCE	ABSENCE
24	Brenna Model House, Phase 1, Laguna Bel-Air 3	Distribution	4/6/2016	11:06 AM	-	ABSENCE	ABSENCE
25	Block 50, Phase 2, Laguna Bel-Air 3	Source	4/6/2016	10:29 AM	2	ABSENCE	ABSENCE
26	Block 66 Lot 6, Wallace St., Laguna Bel-Air 3	Distribution	4/6/2016	10:42 AM	-	ABSENCE	ABSENCE
27	Drinking Fountain, Loma Elementary School	Distribution	4/18/2016	1:14 PM	-	ABSENCE	ABSENCE
BRGY. MALAMIG							
28	Block 5 Lot 16	Distribution	4/18/2016	2:06 PM	<1	ABSENCE	ABSENCE
BRGY. MAMPLASAN							
29	Tank, Verdana Homes Subdivision	Source	4/18/2016	1:45 PM	<1	ABSENCE	ABSENCE
30	Clubhouse, Verdana Homes Subdivision	Distribution	4/18/2016	1:31 PM	-	ABSENCE	ABSENCE
BRGY. POBLACION							
31	9018 WP Public Market 4024 Town Proper	Source	4/26/2016	11:14 AM	<1	ABSENCE	ABSENCE
BRGY. PLATERO							
32	Drinking Fountain, St. Michael School of Biñan	Distribution	4/13/2016	9:34 AM	6	ABSENCE	ABSENCE
33	Sea-oil, National Road	Distribution	4/13/2016	9:48 AM	-	ABSENCE	ABSENCE
BRGY. SAN ANTONIO							

34	9022 Water Pump (WP) Faraon Subdivision	Source	4/26/2016	10:43 AM	1	ABSENCE	ABSENCE
35	Block 5 Lot 12, Margarita Homes Subdivision	Distribution	4/26/2016	9:09 AM	-	ABSENCE	ABSENCE
36	Drinking Fountain 1, Faraon Elementary School	Distribution	4/13/2016	1:10 PM	-	ABSENCE	ABSENCE
37	Drinking Fountain 2, Faraon Elementary School	Distribution	4/13/2016	1:17 PM	-	ABSENCE	ABSENCE
BRGY. SAN VICENTE							
38	9001 GP San Vicente	Source	4/5/2016	11:08 AM	<1	ABSENCE	ABSENCE
39	B12 L5, Bayabas St., Olivarez 7	Distribution	4/5/2016	11:23 AM	<1	ABSENCE	ABSENCE
BRGY. SANTO TOMAS							
40	Phase 2, Adelina Complex III Subdivision	Source	4/18/2016	10:17 AM	<1	ABSENCE	ABSENCE
41	Gate Entrance, Adelina Complex III Subdivision	Distribution	4/18/2016	10:27 AM	-	ABSENCE	ABSENCE
42	1 LT Water Pump, Phase 1B, Olivarez Homes South	Source	4/18/2016	11:33 AM	<1	ABSENCE	ABSENCE
43	Block 1 Lot 26, Phase 3, Olivarez Homes South	Distribution	4/18/2016	11:11 AM	-	ABSENCE	ABSENCE
44	5555 Block 1, Phase 4, Olivarez Homes South	Source	4/18/2016	10:44 AM	<1	ABSENCE	ABSENCE
45	Block 2 ot 9, Phase 4, Olivarez Homes South	Distribution	4/18/2016	11:01 AM	-	ABSENCE	ABSENCE
46	Pump House, Kalibo St., South City Homes	Source	4/5/2016	10:44 AM	<1	ABSENCE	ABSENCE
47	Block 75 Lot 8C, Gingoog St., Pragmatic	Distribution	4/5/2016	10:56 AM	2	ABSENCE	ABSENCE
48	South Plains II Subdivision	Source	4/5/2016	10:23 AM	2	ABSENCE	ABSENCE
49	Block 1 Lot 6, South Plains II Subdivision	Distribution	4/5/2016	10:11 AM	<1	ABSENCE	ABSENCE
50	Pump, Amsterdam St., Phase 2, Town & Country	Source	4/18/2016	12:20 PM	<1	ABSENCE	ABSENCE
51	Block 35 Lot 21, Town & Country	Distribution	4/18/2016	12:09 PM	-	ABSENCE	ABSENCE
52	Water Tank, Pensylvannia St, Town & Country	Source	4/18/2016	11:51 AM	<1	ABSENCE	ABSENCE
53	Block 2 Lot 5, Town & Country	Distribution	4/18/2016	11:58 AM	-	ABSENCE	ABSENCE
BRGY. SORO - SORO							
54	9067 Soro-soro	Source	4/13/2016	12:00 NN	<1	ABSENCE	ABSENCE
55	#76 Soro-Soro	Distribution	4/13/2016	11:25 AM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		55	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES : ³Philippine National Standard for Drinking Water, 2007

: ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY


CYRILA A. ERICA, RMT
Analyst (License No. 0054161)

DATE/TIME

5/2/2016 11:21 AM

CERTIFIED CORRECT


AMPARO C. CAÑAMO
Head of Laboratory

DATE/TIME

May 2, 2016 / 11:30 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007 · (049) 543 1916 (Laboratory Direct Line)

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : SANTA ROSA	MONTH : APRIL	YEAR : 2016
---------------------------------------	----------------------	--------------------

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BALIBAGO							
1	5555 Water Pump Elevated, South Hampton	Source	4/4/2016	12:46 PM	<1	ABSENCE	ABSENCE
2	Block 1 Lot 5, South Hampton	Distribution	4/4/2016	12:53 PM	<1	ABSENCE	ABSENCE
3	Block 11 Lot 2, JB Village, Sta. Rosa Tagaytay Road	Distribution	4/27/2016	1:30 PM	-	ABSENCE	ABSENCE
BRGY. CAINGIN							
4	9002 Block 53, Phase 4, Southville	Source	4/20/2016	12:08 PM	6	ABSENCE	ABSENCE
5	Block 52 Lot 23, Phase 1, Southville	Distribution	4/20/2016	12:15 PM	-	ABSENCE	ABSENCE
BRGY. DILA							
6	Phase 3E, Mabuhay Homes 2000	Source	4/20/2016	11:23 AM	<1	ABSENCE	ABSENCE
7	Block 6 Lot 6, Mabuhay Homes 2000	Distribution	4/20/2016	11:34 AM	-	ABSENCE	ABSENCE
8	Block 12, Phase 2E, Mabuhay Homes 2000	Source	4/20/2016	11:18 AM	<1	ABSENCE	ABSENCE
9	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	Distribution	4/20/2016	10:58 AM	-	ABSENCE	ABSENCE
10	Drinking Fountain, Dila Elementary School	Distribution	4/26/2016	11:03 AM	<1	ABSENCE	ABSENCE
BRGY. DITA							
11	Block 24 Lot 10, New Santa Rosa Homes	Source	4/19/2016	1:47 PM	37	ABSENCE	ABSENCE
12	Block 19 Lot 11, New Santa Rosa Homes	Distribution	4/19/2016	2:01 PM	-	ABSENCE	ABSENCE
13	Block 4 Lot 32, San Lorenzo Royale	Source	4/4/2016	12:10 PM	3	ABSENCE	ABSENCE
14	Block 11 Lot 52, San Lorenzo Royale	Distribution	4/4/2016	11:56 PM	-	ABSENCE	ABSENCE
15	Water Tank, SolCar Ville Subdivision	Source	4/19/2016	2:14 PM	230	ABSENCE	ABSENCE
16	Front Gate, SolCar Ville Subdivision	Distribution	4/19/2016	2:26 PM	-	ABSENCE	ABSENCE
17	Water Tank, Villa Esmeralda	Source	4/4/2016	12:33 PM	<1	ABSENCE	ABSENCE
18	Alabaster St., Villa Esmeralda	Distribution	4/4/2016	12:23 PM	-	ABSENCE	ABSENCE
19	#1780 National Road	Distribution	4/19/2016	2:36 PM	-	ABSENCE	ABSENCE
BRGY. DON JOSE							
20	Block 7 Lot 62, Phase 3, Laguna Bel-Air	Source	4/6/2016	12:03 PM	31	ABSENCE	ABSENCE
21	Science HighSchool, Phase 1, Laguna Bel-Air	Distribution	4/6/2016	12:37 PM	-	ABSENCE	ABSENCE
22	Block 34 Lot 14, Phase 1, Laguna Bel-Air	Source	4/6/2016	11:36 AM	-	ABSENCE	ABSENCE
23	#60 Cypress St., Phase 1, Laguna Bel-Air	Distribution	4/6/2016	11:25 AM	<1	ABSENCE	ABSENCE
24	Clubhouse, Block 62, Laguna Bel-Air	Distribution	4/6/2016	12:52 PM	11	ABSENCE	ABSENCE
25	Water Pump, Block 71, Phase 4, Laguna Bel-Air	Source	4/12/2016	1:25 PM	<1	ABSENCE	ABSENCE
26	Block 71 Lot 4, Phase 2, Laguna Bel-Air	Distribution	4/12/2016	1:30 PM	-	ABSENCE	ABSENCE
27	Block 108, Phase 5, Laguna Bel-Air	Source	4/6/2016	8:50 AM	<1	ABSENCE	ABSENCE
28	Church, Block 108, Phase 2, Laguna Bel-Air	Distribution	4/6/2016	9:05 AM	-	ABSENCE	ABSENCE
29	1NR Block 43, Laguna Bel-Air IV	Source	4/6/2016	12:16 PM	<1	ABSENCE	ABSENCE
30	Block 47 Lot 12 Laguna Bel-Air IV	Distribution	4/6/2016	12:25 PM	-	ABSENCE	ABSENCE
31	8001, Pump 1, Acacia St., Santa Rosa Village I	Source	4/11/2016	1:18 PM	<1	ABSENCE	ABSENCE
32	109 Saraca St., Santa Rosa Village I	Distribution	4/11/2016	1:27 PM	-	ABSENCE	ABSENCE
33	Pump 9 & 10, Rembrandt St., Santa Rosa Estates I	Source	4/11/2016	2:04 PM	7	ABSENCE	ABSENCE
34	101 Elde France St., Phase 4A, Santa Rosa Village II	Distribution	4/11/2016	1:47 PM	2	ABSENCE	ABSENCE
35	Clubhouse, Santa Rosa Estates I	Distribution	4/11/2016	2:14 PM	-	ABSENCE	ABSENCE
36	Reservoir, Hacienda Sta. Elena	Distribution	4/27/2016	11:20 AM	<1	ABSENCE	ABSENCE
BRGY. KANLURAN							
37	Malusak Bakery, #621 Rizal Boulevard	Distribution	4/25/2016	11:11 AM	-	ABSENCE	ABSENCE
BRGY. MACABLING							
38	Deepwell, Buena Rosa 9 Subdivision	Source	4/27/2016	12:18 PM	<1	ABSENCE	ABSENCE

39	Block 3 Lot 1, Phase 2, Buena Rosa 9 Subdivision	Distribution	4/27/2016	12:28 PM	-	ABSENCE	ABSENCE
40	Deepwell, Corinthian Subdivision	Source	4/27/2016	12:37 PM	<1	ABSENCE	ABSENCE
41	Guardhouse, Corinthian Subdivision	Distribution	4/27/2016	12:47 PM	-	ABSENCE	ABSENCE
42	Deepwell, Rosemont Subdivision	Source	4/27/2016	11:51 AM	<1	ABSENCE	ABSENCE
43	Block 4 Lot 7, Rosemont Subdivision	Distribution	4/27/2016	12:02 PM	-	ABSENCE	ABSENCE
BRGY. MALITLIT							
44	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	Source	4/4/2016	10:29 AM	1	ABSENCE	ABSENCE
45	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	Distribution	4/4/2016	10:34 AM	-	ABSENCE	ABSENCE
46	Main Road, Phase 2, Terra Fortuna	Source	4/12/2016	12:45 PM	95	ABSENCE	ABSENCE
47	Block 11 Lot 16, Terra Fortuna	Distribution	4/12/2016	12:58 PM	-	ABSENCE	ABSENCE
48	9999 W, Villa Las Casas	Source	4/4/2016	10:51 AM	-	ABSENCE	ABSENCE
49	Block 1 Lot 15, Villa Las Casas	Distribution	4/4/2016	11:04 AM	<1	ABSENCE	ABSENCE
BRGY. MARKET AREA							
50	Source, Market Area	Source	4/25/2016	1:20 PM	<1	ABSENCE	ABSENCE
51	Block 9 Lot 2, Terry Town West	Distribution	4/25/2016	11:45 AM	-	ABSENCE	ABSENCE
BRGY. POOC							
52	Deepwell, Alinsod	Source	4/20/2016	1:00 PM	<1	ABSENCE	ABSENCE
53	Block 13 Lot 34, Alinsod	Distribution	4/20/2016	1:26 PM	-	ABSENCE	ABSENCE
54	9999 Water Pump, Phase 5, Southville	Source	4/20/2016	12:31 PM	<1	ABSENCE	ABSENCE
55	Block 46 Lot 2, Phase 2, Southville	Distribution	4/20/2016	12:22 PM	-	ABSENCE	ABSENCE
BRGY. PULONG SANTA CRUZ							
56	Water Pump, Pulong Sta. Cruz	Source	4/4/2016	9:43 AM	1	ABSENCE	ABSENCE
57	Purok 5, Sitio Arattan	Distribution	4/4/2016	9:22 AM	1	ABSENCE	ABSENCE
58	Block 6 Lot 8, Buklod Diwa	Distribution	4/27/2016	10:57 AM	<1	ABSENCE	ABSENCE
BRGY. SINALHAN							
59	Source, Bayshore I	Source	4/25/2016	1:04 PM	<1	ABSENCE	ABSENCE
60	Block 9 Lot 14, Bristol Bay St., Bayshore II	Distribution	4/25/2016	12:49 PM	-	ABSENCE	ABSENCE
61	4026, Sinalhan Road, Purok 2	Source	4/25/2016	12:15 PM	<1	ABSENCE	ABSENCE
62	Purok 4, Sinalhan	Distribution	4/25/2016	12:25 PM	-	ABSENCE	ABSENCE
BRGY. STO. DOMINGO							
63	Laguna Water Head Office, One Evotech Bldg. Nuvali	Distribution	4/27/2016	3:40 PM	<1	ABSENCE	ABSENCE
64	Clubhouse Santa Rosa Estates II	Distribution	4/11/2016	2:29 PM	<1	ABSENCE	ABSENCE
BRGY. TAGAPO							
65	Water Pump, Metrogate	Source	4/27/2016	11:24 AM	<1	ABSENCE	ABSENCE
66	Clubhouse, Metrogate	Distribution	4/27/2016	11:36 AM	-	ABSENCE	ABSENCE
67	Water Pump, Rosewood	Source	4/27/2016	10:36 AM	<1	ABSENCE	ABSENCE
68	Block 4 Lot 11, Rosewood	Distribution	4/27/2016	10:44 AM	-	ABSENCE	ABSENCE
69	Block 4 Lot 1, Phase 2, Rosewood II	Distribution	4/27/2016	11:00 AM	-	ABSENCE	ABSENCE
70	#31 JP Rizal Boulevard	Distribution	4/27/2016	11:12 AM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		70	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES : ³Philippine National Standard for Drinking Water, 2007

: ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT

Analyst (License No. 0054161)

CERTIFIED CORRECT



AMPARO C. CAÑAMO

Head of Laboratory

DATE/TIME

5/2/2016 11:21 am

DATE/TIME

May 2, 2016 11:45 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007 · (049) 543 1916 (Laboratory Direct Line)

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : CABUYAO	MONTH : APRIL	YEAR : 2016
------------------------------------	----------------------	--------------------

NO	SAMPLE LOCATION ADDRESS	TYPE	DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
						TOTAL	<i>Escherichia coli</i>
BRGY. BIGAA							
1	#253 Elsol Subdivision	Distribution	4/19/2016	1:29 PM	<1	ABSENCE	ABSENCE
BRGY. CASILE							
2	Matang Tubig Spring	Source	4/27/2016	11:43 AM	<1	ABSENCE	ABSENCE
BRGY. GULOD							
3	Block 12, Noah St., Celestine Ville	Source	4/4/2016	11:03 AM	3	ABSENCE	ABSENCE
4	Guardhouse, Celestine Ville Avenue, Celestine Ville	Distribution	4/4/2016	11:33 AM	1	ABSENCE	ABSENCE
BRGY. MAMATID							
5	Tank, Buena Rosario Subdivision	Source	4/19/2016	10:26 AM	<1	ABSENCE	ABSENCE
6	Block 2, Buena Rosario Subdivision	Distribution	4/19/2016	10:53 AM	-	ABSENCE	ABSENCE
7	Block 101 Samar st., Phase 2, Mabuhay City	Source	4/4/2016	9:53 AM	<1	ABSENCE	ABSENCE
8	Block 95 Lot 57, Guimaras St., Phase 1, Mabuhay City	Distribution	4/4/2016	10:06 AM	-	ABSENCE	ABSENCE
9	Block 141, Carmona St., Phase 2, Mabuhay City	Source	4/4/2016	10:34 AM	<1	ABSENCE	ABSENCE
10	Block 4 Lot 20, Phase 2, Mabuhay City	Distribution	4/4/2016	10:45 AM	2	ABSENCE	ABSENCE
11	Block 198, Galacia St., Phase 2, Mabuhay City	Source	4/4/2016	9:27 AM	<1	ABSENCE	ABSENCE
12	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay	Distribution	4/4/2016	9:35 AM	-	ABSENCE	ABSENCE
13	Panganig St., Phase 3 Cluster, Mabuhay City	Source	4/4/2016	12:30 PM	<1	ABSENCE	ABSENCE
14	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	Distribution	4/4/2016	12:35 PM	-	ABSENCE	ABSENCE
15	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	Source	4/4/2016	1:00 PM	<1	ABSENCE	ABSENCE
16	Block 19 Lot 13, Malang St., Phase 3 Luxury, Mabuhay	Distribution	4/4/2016	1:10 PM	-	ABSENCE	ABSENCE
17	Joshua St., Phase 5, Mabuhay City	Source	4/4/2016	1:25 PM	<1	ABSENCE	ABSENCE
18	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	Distribution	4/4/2016	1:46 PM	-	ABSENCE	ABSENCE
BRGY. MARINIG							
19	Block 3 Lot 17, Phase 1, Celestine Homes	Source	4/19/2016	11:23 AM	<1	ABSENCE	ABSENCE
20	Block 26, Lot 4, Phase 1, Celestine Homes	Distribution	4/19/2016	11:34 AM	-	ABSENCE	ABSENCE
21	Block 9, Carnation St., Phase 2, Celestine Homes	Source	4/19/2016	11:44 AM	-	ABSENCE	ABSENCE
22	Block 11 Lot 9, Phase 2, Celestine Homes	Distribution	4/19/2016	11:52 AM	<1	ABSENCE	ABSENCE
23	Block 25, Phase 3, Southville	Source	4/19/2016	12:36 PM	<1	ABSENCE	ABSENCE
24	Block 19 Lot 33, Phase 3, Southville	Distribution	4/19/2016	12:43 PM	-	ABSENCE	ABSENCE
BRGY. NIUGAN							
25	Water Pump, Niugan Elementary School Compound	Source	4/12/2016	10:17 AM	<1	ABSENCE	ABSENCE
26	Patricia's Apartment, St. Francis 7	Distribution	4/12/2016	10:33 AM	-	ABSENCE	ABSENCE
27	Block 45, Phase 8, Southville	Source	4/20/2016	10:41 AM	80	ABSENCE	ABSENCE
28	Block 41 Lot 106, Southville	Distribution	4/19/2016	12:10 PM	-	ABSENCE	ABSENCE
29	Block 54, Phase 10, Southville	Source	4/12/2016	11:04 AM	<1	ABSENCE	ABSENCE
30	Block 47 Lot 101, Phase 10, Southville	Distribution	4/12/2016	11:17 AM	-	ABSENCE	ABSENCE
BRGY. PULO							
31	Block 12 Lot 22, Cabuyao Central	Source	4/12/2016	8:44 AM	<1	ABSENCE	ABSENCE
32	Clubhouse, Narra Avenue, Cabuyao Central	Distribution	4/12/2016	8:58 AM	<1	ABSENCE	ABSENCE
33	Block 11, Willow Park Homes	Source	4/12/2016	9:32 AM	3	ABSENCE	ABSENCE
34	Guardhouse, Main St., Willow Park Homes	Distribution	4/12/2016	9:55 AM	<1	ABSENCE	ABSENCE
BRGY. SALA							
35	Guardhouse, Main St., Multiland III	Distribution	4/4/2016	2:03 PM	-	ABSENCE	ABSENCE
BRGY. SAN ISIDRO							
36	Block 3 Lot 33, Multiland IV	Distribution	4/4/2016	2:34 PM	-	ABSENCE	ABSENCE

TOTAL SAMPLES ANALYZED	36	2007 PNSDW LIMIT ³	<500	ABSENCE	ABSENCE
------------------------	----	-------------------------------	------	---------	---------

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

DATE/TIME

5/2/2016 11:21 AM

CERTIFIED CORRECT



AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

May 2, 2016 12:00 NN

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007 · (049) 543 1916 (Laboratory Direct Line)

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : CALAMBA	MONTH : APRIL	YEAR : 2016
-----------------------------	---------------	-------------

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BARANDAL							
1	Deepwell 1, Amaia Scapes Calamba	Source	4/27/2016	9:35 AM	<1	ABSENCE	ABSENCE
2	Block 39 Lot 1, Amaia Scapes Calamba	Distribution	4/27/2016	9:47 AM	-	ABSENCE	ABSENCE
3	Deepwell 2, Amaia Scapes Calamba	Source	4/27/2016	10:04 AM	<1	ABSENCE	ABSENCE
4	Block 23 Lot 31, Amaia Scapes Calamba	Distribution	4/27/2016	10:10 AM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		4	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

DATE/TIME

5/2/2016 11:21 Am

CERTIFIED CORRECT



AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

may 2, 2016 11:45 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007 · (049) 543 1916 (Laboratory Direct Line)

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : ALAMINOS	MONTH : APRIL	YEAR : 2016
-------------------------------------	----------------------	--------------------

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. SAN ANDRES							
1	Water Tank, Bellavita Homes	Source	4/27/2016	4:50 PM	<1	ABSENCE	ABSENCE
2	Block 21 Lot 18, BellaVita Homes	Distribution	4/27/2016	5:00 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

DATE/TIME

5/2/2016 11:21am

CERTIFIED CORRECT



AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

May 2, 2016 / 11:30 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007 · (049) 543 1916 (Laboratory Direct Line)

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : SANTA CRUZ	MONTH : APRIL	YEAR : 2016
---------------------------------------	----------------------	--------------------

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BUBUKAL							
1	Source after Filter, Laguna Sports Complex	Source	4/27/2016	1:54 PM	<1	ABSENCE	ABSENCE
2	Canteen No. 4 in front of Laguna University Administration Building	Distribution	4/27/2016	2:10 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

DATE/TIME

5/2/2016 11:21am

CERTIFIED CORRECT



AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

May 2, 2016 11:35 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007 · (049) 543 1916 (Laboratory Direct Line)