

No.	LOCATION (BIÑAN CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
	Sampling Point	Barangay					
1	Adelina Deepwell	Brgy. Sto. Tomas, Biñan	1/11/2016	10:20 AM	62	ABSENT	<0.30
2	Gate Entrance, Adelina	Brgy. Sto. Tomas, Biñan	1/11/2016	10:27 AM	-	ABSENT	<0.30
3	Source, Almeda	Brgy. Dela Paz, Biñan	1/12/2016	10:37 AM	8	ABSENT	<0.30
4	Brgy. Hall	Brgy. Dela Paz, Biñan	1/12/2016	11:01 AM	-	ABSENT	<0.30
5	Source, Malaban Faraon	Brgy. San Antonio, Biñan	1/12/2016	9:17 AM	467	ABSENT	<0.30
6	Block 5 Lot 12, Margarita Homes	Brgy. San Antonio, Biñan	1/12/2016	8:54 AM	-	ABSENT	<0.30
7	Source, Southville Langkiwa	Brgy. Langkiwa, Biñan	1/26/2016	1:51 PM	<1	ABSENT	<0.30
8	Block 40, Phase 20, Southville Langkiwa	Brgy. Langkiwa, Biñan	1/26/2016	1:59 PM	-	ABSENT	<0.30
9	Tank, Metroville	Brgy. Canlalay, Biñan	1/6/2016	12:26 PM	<1	ABSENT	1.33
10	Clubhouse, Metroville	Brgy. Halang, Biñan	1/6/2016	12:48 PM	-	ABSENT	1.26
11	Source, Phase 1B Olivarez Subdivision	Brgy. Sto. Tomas, Biñan	1/11/2016	11:43 AM	<1	ABSENT	2.81
12	Block 1 Lot 26, Olivarez Phase 3	Brgy. Sto. Tomas, Biñan	1/11/2016	11:33 AM	-	ABSENT	2.88
13	Block 1 Lot 16, Olivarez Phase 4	Brgy. Sto. Tomas, Biñan	1/11/2016	10:57 AM	4	ABSENT	0.76
14	Block 2 Lot 9, Olivarez Phase 4	Brgy. Sto. Tomas, Biñan	1/11/2016	11:11 AM	-	ABSENT	0.79
15	Brgy. Hall - Poblacion	Brgy. Poblacion, Biñan	1/12/2016	10:08 AM	198	ABSENT	<0.30
16	#84A, Bonifacio St.	Brgy. Canlalay, Biñan	1/12/2016	11:25 AM	-	ABSENT	<0.30
17	Golden City Canlalay - Clubhouse	Brgy. Canlalay, Biñan	1/6/2016	12:48 PM	-	ABSENT	1.08
18	Block 75 Lot 8C Ginggaog St., Pragmatic	Brgy. Sto. Tomas, Biñan	1/5/2016	10:08 AM	<1	ABSENT	0.82
19	Bais St., Pragmatic	Brgy. Sto. Tomas, Biñan	1/5/2016	10:24 AM	-	ABSENT	0.81
20	#407, San Vicente	Brgy. San Vicente, Biñan	1/5/2016	9:29 AM	<1	ABSENT	<0.30
21	B12 L5, Bayabas St. Olivarez 7	Brgy. San Vicente, Biñan	1/5/2016	9:43 AM	-	ABSENT	0.33
22	Source, Soro-Soro	Brgy. Soro-soro, Biñan	1/6/2016	2:14 PM	<1	ABSENT	<0.30
23	#76, Soro-Soro	Brgy. Soro-soro, Biñan	1/6/2016	1:10 PM	-	ABSENT	<0.30
24	South Plains II Deepwell	Brgy. Sto. Tomas, Biñan	1/5/2016	10:40 AM	<1	ABSENT	1.69
25	Block 11 Lot 6, South Plains II	Brgy. Sto. Tomas, Biñan	1/5/2016	11:16 AM	-	ABSENT	0.99
26	Town & Country Amsterdam Deepwell	Brgy. Sto. Tomas, Biñan	1/11/2016	12:07 PM	6	ABSENT	<0.30
27	Town & Country Block 35 Lot 21-Amsterdam	Brgy. Sto. Tomas, Biñan	1/11/2016	12:14 PM	-	ABSENT	<0.30
28	Town & Country Pennsylvania Deepwell	Brgy. Sto. Tomas, Biñan	1/26/2016	1:15 PM	<1	ABSENT	1.99
29	Town & Country Block 2 Lot 5	Brgy. Sto. Tomas, Biñan	1/26/2016	1:28 PM	-	ABSENT	1.78
30	Source 1, Verdana Subdivision	Brgy. Mamlasan, Biñan	1/26/2016	2:40 PM	<1	ABSENT	0.72
31	Block 5, Lot 16	Brgy. Malamig, Biñan	1/26/2016	3:14 PM	-	ABSENT	0.42
32	Drinking Fountain, Canlalay Elementary School	Brgy. Canlalay, Biñan	1/6/2016	12:06 PM	-	ABSENT	<0.30
33	Drinking Fountain, Dela Paz Elementary School	Brgy. Dela Paz, Biñan	1/12/2016	9:59 AM	<1	ABSENT	<0.30
34	Drinking Fountain, Ganado Elementary School	Brgy. Mamlasan, Biñan	1/5/2016	11:50 AM	-	ABSENT	<0.30
35	Drinking Fountain, Loma Elementary School	Brgy. Malamig, Biñan	1/26/2016	2:57 PM	-	ABSENT	0.58
36	Drinking Fountain 1, Malaban Faraon Elem. School	Brgy. San Antonio, Biñan	1/12/2016	9:36 AM	-	ABSENT	<0.30
37	Drinking Fountain 2, Malaban Faraon Elem. School	Brgy. San Antonio, Biñan	1/12/2016	9:45 AM	-	ABSENT	<0.30
38	Drinking Fountain, St. Michael School of Biñan	Brgy. Platero, Biñan	1/6/2016	11:14 AM	<1	ABSENT	<0.30
39	Sea-oil	Brgy. Platero, Biñan	1/6/2016	11:25 AM	-	ABSENT	<0.30
PNSDW LIMIT					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method

Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT
Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 534 1627 · (02) 519 4887

LOCATION (SANTA ROSA CITY)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
#	Sampling Point	Barangay					
1	Alinsod Deepwell	Brgy. Pooc, Sta. Rosa	1/25/2016	11:01 AM	<1	ABSENT	0.54
2	Block 13 Lot 34, Alinsod	Brgy. Pooc, Sta. Rosa	1/25/2016	11:14 AM	-	ABSENT	<0.30
3	Source, Bayshore 1	Brgy. Sinalhan, Sta. Rosa	1/13/2016	9:33 AM	<1	ABSENT	<0.30
4	Block 1 Lot 9, Phase 1, Bayshore 1	Brgy. Sinalhan, Sta. Rosa	1/13/2016	9:43 AM	-	ABSENT	<0.30
5	Source, Bayshore 2	Brgy. Sinalhan, Sta. Rosa	1/13/2016	9:15 AM	<1	ABSENT	<0.30
6	Block 8 Lot 6 Phase 3, Bayshore 2	Brgy. Sinalhan, Sta. Rosa	1/13/2016	9:04 AM	-	ABSENT	<0.30
7	Cobassuise Deepwell	Brgy. Malitlit, Sta. Rosa	1/5/2016	11:22 AM	<1	ABSENT	0.62
8	Cobassuise Block 5 Lot 25	Brgy. Malitlit, Sta. Rosa	1/5/2016	11:30 AM	-	ABSENT	0.66
9	Golden City Ph 1E/3E Deepwell	Brgy. Dila, Sta. Rosa	1/25/2016	10:26 AM	<1	ABSENT	0.60
10	Golden City Ph 1E/3E Block 6 Lot 6	Brgy. Dila, Sta. Rosa	1/25/2016	10:39 AM	-	ABSENT	0.55
11	Golden City Ph 2E Deepwell	Brgy. Dila, Sta. Rosa	1/25/2016	9:58 AM	<1	ABSENT	<0.30
12	Golden City Ph 2E Block 13 Lot 5	Brgy. Dila, Sta. Rosa	1/25/2016	10:10 AM	-	ABSENT	<0.30
13	Laguna Bel-Air 1 Block 7 Deepwell	Brgy. Don Jose, Sta. Rosa	1/19/2016	2:30 PM	<1	ABSENT	0.70
14	Laguna Bel-Air 1 Block 7 Lot 74	Brgy. Don Jose, Sta. Rosa	1/19/2016	1:58 PM	-	ABSENT	0.49
15	Laguna Bel-Air 1 Block 34 Deepwell	Brgy. Don Jose, Sta. Rosa	1/26/2016	10:54 AM	<1	ABSENT	0.64
16	Laguna Bel-Air 1 Block 34 Lot 59	Brgy. Don Jose, Sta. Rosa	1/26/2016	10:42 AM	-	ABSENT	0.67
17	Laguna Bel-Air 2 Block 71 Deepwell	Brgy. Don Jose, Sta. Rosa	1/25/2016	9:05 AM	<1	ABSENT	0.54
18	Laguna Bel-Air 2 Block 71 Lot 4	Brgy. Don Jose, Sta. Rosa	1/25/2016	9:12 AM	-	ABSENT	0.57
19	Laguna Bel-Air 2 Block 108 Deepwell	Brgy. Don Jose, Sta. Rosa	1/19/2016	1:37 PM	<1	ABSENT	0.33
20	Laguna Bel-Air 2 Block 108 - Church	Brgy. Don Jose, Sta. Rosa	1/19/2016	1:44 PM	-	ABSENT	<0.30
21	Laguna Bel-Air 3 Block 2 Deepwell	Brgy. Loma, Sta. Rosa	1/26/2016	9:48 AM	<1	ABSENT	0.61
22	Laguna Bel-Air 3 Block 2 (Hillcrest Road)	Brgy. Loma, Sta. Rosa	1/26/2016	9:59 AM	-	ABSENT	0.53
23	Laguna Bel-Air 3 Block 8	Brgy. Loma, Sta. Rosa	1/26/2016	10:30 AM	<1	ABSENT	<0.30
24	Laguna Bel-Air 3 Block 8 Brenna Model House	Brgy. Loma, Sta. Rosa	1/26/2016	10:19 AM	-	ABSENT	<0.30
25	Laguna Bel-Air 3 Block 50 Deepwell	Brgy. Loma, Sta. Rosa	1/26/2016	10:09 AM	<1	ABSENT	0.42
26	Laguna Bel-Air 3 - Clubhouse	Brgy. Loma, Sta. Rosa	1/26/2016	9:34 AM	-	ABSENT	<0.30
27	Laguna Bel-Air 4 Block 43 Deepwell	Brgy. Don Jose, Sta. Rosa	1/19/2016	2:13 PM	<1	ABSENT	0.69
28	Laguna Bel-Air 4 Block 47 Lot 12	Brgy. Don Jose, Sta. Rosa	1/19/2016	2:20 PM	-	ABSENT	0.82
29	Source, Market Area	Brgy. Balibago, Sta. Rosa	1/13/2016	9:54 AM	<1	ABSENT	<0.30
30	Block 9 Lot 2, Terry Town West, Market Area	Brgy. Balibago, Sta. Rosa	1/13/2016	10:14 AM	-	ABSENT	<0.30
31	Metrogate, Tank	Brgy. Tagapo, Sta. Rosa	1/5/2016	2:06 PM	<1	ABSENT	1.48
32	Rosa Subd., Metrogate	Brgy. Macabaling, Sta. Rosa	1/5/2016	1:38 PM	-	ABSENT	1.08
33	Block 24 Lot 10, New Santa Rosa Homes (near DW)	Brgy. Dita, Sta. Rosa	1/13/2016	10:08 AM	<1	ABSENT	1.93
34	Block 19 Lot 6, New Santa Rosa Homes	Brgy. Dita, Sta. Rosa	1/13/2016	10:25 AM	-	ABSENT	1.90
35	Source, Pulong Santa Cruz	Brgy. Pulong Sta. Cruz, Sta. Rosa	1/25/2016	8:44 AM	<1	ABSENT	0.83
36	Purok 5, Sitio Arattan	Brgy. Pulong Sta. Cruz, Sta. Rosa	1/25/2016	8:31 AM	-	ABSENT	0.67
37	Source, Rosewood	Brgy. Halang, Sta. Rosa	1/27/2016	12:55 PM	<1	ABSENT	0.31
38	Block 1 Lot 18, Rosewood	Brgy. Halang, Sta. Rosa	1/27/2016	1:08 PM	-	ABSENT	<0.30
39	San Lorenzo Royale Deepwell	Brgy. Dita, Sta. Rosa	1/25/2016	12:01 PM	<1	ABSENT	0.36
40	Block 11 Lot 52, San Lorenzo Royale	Brgy. Dita, Sta. Rosa	1/25/2016	12:11 PM	-	ABSENT	0.44
41	Purok 2 near Deepwell, Sinalhan	Brgy. Sinalhan, Sta. Rosa	1/13/2016	8:25 AM	<1	ABSENT	<0.30
42	Purok 4, Sinalhan	Brgy. Sinalhan, Sta. Rosa	1/13/2016	8:48 AM	-	ABSENT	<0.30
43	Sol-Car Deepwell	Brgy. Dita, Sta. Rosa	1/13/2016	9:33 AM	<1	ABSENT	0.86
44	Front Gate, Sol-Car	Brgy. Dita, Sta. Rosa	1/13/2016	9:45 AM	-	ABSENT	0.73
45	Deepwell 1, Santa Rosa Village I	Brgy. Don Jose, Sta. Rosa	1/11/2016	9:54 AM	<1	ABSENT	0.65
46	Clubhouse, Santa Rosa Village I	Brgy. Don Jose, Sta. Rosa	1/11/2016	10:03 AM	-	ABSENT	<0.30
47	Deepwell 6, Phase 4C, San Jose Village I	Brgy. Don Jose, Sta. Rosa	1/11/2016	10:52 AM	48	ABSENT	<0.30
48	Deepwell 2, San Jose Village I - Phase 3B	Brgy. Don Jose, Sta. Rosa	1/4/2016	2:14 PM	<1	ABSENT	0.83
49	Clubhouse, San Jose Village I - Phase 3B	Brgy. Don Jose, Sta. Rosa	1/11/2016	11:39 AM	-	ABSENT	<0.30
50	Clubhouse., San Jose Village I - Phase 4C	Brgy. Don Jose, Sta. Rosa	1/11/2016	10:44 AM	-	ABSENT	0.37
51	Deepwell 11, San Jose Village II - Phase V	Brgy. Don Jose, Sta. Rosa	1/4/2016	3:43 PM	12	ABSENT	0.65
52	Clubhouse, San Jose Village II - Phase V	Brgy. Don Jose, Sta. Rosa	1/11/2016	11:02 AM	-	ABSENT	1.11
53	Deepwell 7, San Jose Village III - Phase VI	Brgy. Don Jose, Sta. Rosa	1/11/2016	11:28 AM	31	ABSENT	<0.30
54	Clubhouse, San Jose Village III - Phase VI	Brgy. Don Jose, Sta. Rosa	1/11/2016	11:16 AM	-	ABSENT	<0.30
55	Booster Tank, Santa Rosa Estates	Brgy. Don Jose, Sta. Rosa	1/4/2016	3:17 PM	<1	ABSENT	<0.30
56	Clubhouse, Santa Rosa Village II	Brgy. Don Jose, Sta. Rosa	1/4/2016	2:42 PM	-	ABSENT	1.56
57	Clubhouse, Santa Rosa Estates I	Brgy. Don Jose, Sta. Rosa	1/4/2016	3:25 PM	-	ABSENT	1.58
58	Clubhouse, Santa Rosa Estates II	Brgy. Don Jose, Sta. Rosa	1/4/2016	3:01 PM	-	ABSENT	1.42
59	Southville Caingin Phase 1, Block 52 Lot 23	Brgy. Caingin, Sta. Rosa	1/27/2016	12:39 PM	<1	ABSENT	<0.30
60	Southville Caingin Phase 1, Block 57 Lot 17	Brgy. Caingin, Sta. Rosa	1/27/2016	12:31 PM	-	ABSENT	<0.30
61	Southville Caingin Phase 5, Block 1 Lot 34	Brgy. Pooc, Sta. Rosa	1/27/2016	11:47 AM	<1	ABSENT	0.41
62	Southville Caingin Phase 2, Block 46 Lot 2	Brgy. Pooc, Sta. Rosa	1/27/2016	12:14 PM	-	ABSENT	<0.30
63	Tank, South Hampton	Brgy. Balibago, Sta. Rosa	1/25/2016	11:38 AM	<1	ABSENT	0.38
64	Clubhouse, South Hampton	Brgy. Balibago, Sta. Rosa	1/25/2016	11:48 AM	-	ABSENT	0.34
65	Terra Fortuna Deepwell	Brgy. Malitlit, Sta. Rosa	1/5/2016	12:36 PM	<1	ABSENT	<0.30
66	Block 11 Lot 16, Terra Fortuna	Brgy. Malitlit, Sta. Rosa	1/5/2016	12:46 PM	-	ABSENT	<0.30
67	Villa Esmeralda Deepwell	Brgy. Dita, Sta. Rosa	1/25/2016	12:26 PM	<1	ABSENT	0.56
68	Villa Esmeralda Block (Alabaster St.)	Brgy. Dita, Sta. Rosa	1/25/2016	12:38 PM	-	ABSENT	0.51
69	Villa Las Casas Deepwell	Brgy. Malitlit, Sta. Rosa	1/5/2016	11:43 AM	<1	ABSENT	<0.30
70	Villa Las Casas Oval Entrance	Brgy. Malitlit, Sta. Rosa	1/5/2016	12:12 PM	-	ABSENT	0.49
71	Reservoir, Mesaland	Brgy. Don Jose, Sta. Rosa	1/26/2016	10:43 AM	<1	ABSENT	1.19
72	Block 6 Lot 8 Buklod Diwa	Brgy. Pulong Sta. Cruz, Sta. Rosa	1/26/2016	10:08 AM	<1	ABSENT	0.77
73	Home Along Store	Brgy. Malusak, Sta. Rosa	1/13/2016	11:05 AM	-	ABSENT	0.54
74	Block 11 Lot 2, JB Village	Brgy. Balibago, Sta. Rosa	1/5/2016	2:29 PM	-	ABSENT	0.72

75	#1780	Brgy. Dita, Sta. Rosa	1/13/2016	9:15 AM	-	ABSENT	0.54
76	#31 J. P. Rizal Blvd.	Brgy. Tagapo, Sta. Rosa	1/5/2016	2:29 PM	-	ABSENT	0.72
77	Drinking Fountain, Caingin Elementary School	Brgy. Caingin, Sta. Rosa	1/27/2016	12:58 PM	-	ABSENT	<0.30
78	Drinking Fountain, Dila Elementary School	Brgy. Dila, Sta. Rosa	1/13/2016	8:56 AM	-	ABSENT	0.58
79	Drinking Fountain, Front Gate, Central 1 Elem. Sch.	Brgy. Malusak, Sta. Rosa	1/19.2016	1:32 PM	-	ABSENT	0.85
80	Drinking Fountain, Roberto Gonzales Bldg. 1, Central 1 Elementary School	Brgy. Malusak, Sta. Rosa	1/19.2016	1:25 PM	-	ABSENT	0.88
81	Drinking Fountain, Roberto Gonzales Bldg. 2, Central 1 Elementary School	Brgy. Tagapo, Sta. Rosa	1/19.2016	1:18 PM	-	ABSENT	0.75
PNSDW LIMIT							
					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT
Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Company
2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026
Telephone Number: (049) 534 1627 · (02) 519 4887

LOCATION (CABUYAO CITY)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
#	Sampling Point	Barangay					
1	Cabuyao Central Deepwell	Brgy. Pulo, Cabuyao	1/18/2016	9:38 AM	<1	ABSENT	0.44
2	Cabuyao Central Clubhouse	Brgy. Pulo, Cabuyao	1/18/2016	9:49 AM	-	ABSENT	1.07
3	Block 3 Lot 17, Celestine Phase 1	Brgy. Marinig, Cabuyao	1/12/2016	11:15 AM	<1	ABSENT	<0.30
4	Block 26 Lot 4, Celestine Phase 1	Brgy. Marinig, Cabuyao	1/12/2016	12:07 PM	-	ABSENT	<0.30
5	Source, Celestine Phase 2	Brgy. Marinig, Cabuyao	1/12/2016	11:52 AM	<1	ABSENT	<0.30
6	Celestine Phase 2 Block 11 Lot 19	Brgy. Marinig, Cabuyao	1/12/2016	11:37 AM	-	ABSENT	<0.30
7	Celestine Ville Deepwell	Brgy. Gulod, Cabuyao	1/26/2016	8:17 AM	<1	ABSENT	<0.30
8	Guardhouse, Celestine Ville	Brgy. Gulod, Cabuyao	1/26/2016	8:42 AM	-	ABSENT	<0.30
9	Mabuhay Phase 1 Block 101 Deepwell	Brgy. Mamatid, Cabuyao	1/26/2016	9:37 AM	<1	ABSENT	<0.30
10	Mabuhay Phase 1 Block 95 Lot 57	Brgy. Mamatid, Cabuyao	1/26/2016	9:52 AM	-	ABSENT	<0.30
11	Mabuhay Phase 2 Block 141 Deepwell	Brgy. Mamatid, Cabuyao	1/26/2016	9:02 AM	2	ABSENT	<0.30
12	Mabuhay Phase 2 Block 4 Lot 20	Brgy. Mamatid, Cabuyao	1/26/2016	9:12 AM	-	ABSENT	<0.30
13	Mabuhay Phase 2 Block 198 Deepwell	Brgy. Mamatid, Cabuyao	1/26/2016	10:25 AM	1	ABSENT	<0.30
14	Mabuhay Phase 2 Block 222 Lot 20	Brgy. Mamatid, Cabuyao	1/26/2016	10:05 AM	-	ABSENT	<0.30
15	Mabuhay Phase 3 Cluster Deepwell	Brgy. Mamatid, Cabuyao	1/6/2016	10:03 AM	<1	ABSENT	<0.30
16	Mabuhay Phase 3 Cluster Block 1 Lot 17	Brgy. Mamatid, Cabuyao	1/6/2016	10:27 AM	-	ABSENT	<0.30
17	Mabuhay Phase 3 Luxury Deepwell	Brgy. Mamatid, Cabuyao	1/6/2016	10:52 AM	<1	ABSENT	<0.30
18	Mabuhay Phase 3 Luxury Block 19 Lot 13	Brgy. Mamatid, Cabuyao	1/6/2016	10:38 AM	-	ABSENT	0.30
19	Mabuhay Phase 5 Deepwell	Brgy. Mamatid, Cabuyao	1/6/2016	9:48 AM	<1	ABSENT	<0.30
20	Mabuhay Phase 5 Block 31 Lot 134	Brgy. Mamatid, Cabuyao	1/6/2016	9:57 AM	-	ABSENT	<0.30
21	Source, Multi-Land III	Brgy. Sala, Cabuyao	1/13/2016	10:50 AM	<1	ABSENT	<0.30
22	Guardhouse, Multi-Land III	Brgy. Sala, Cabuyao	1/13/2016	11:02 AM	-	ABSENT	<0.30
23	Multi-Land IV Deepwell	Brgy. San Isidro, Cabuyao	1/6/2016	9:20 AM	<1	ABSENT	<0.30
24	Multi-Land IV Block 3 Lot 33	Brgy. San Isidro, Cabuyao	1/6/2016	9:31 AM	-	ABSENT	<0.30
25	Source, Niugan	Brgy. Niugan, Cabuyao	1/18/2016	11:38 AM	<1	ABSENT	<0.30
26	Patricia's Apartment, Niugan	Brgy. Niugan, Cabuyao	1/18/2016	11:49 AM	-	ABSENT	1.03
27	Southville Tank 1 Blk 25 Deepwell	Brgy. Marinig, Cabuyao	1/12/2016	12:25 PM	<1	ABSENT	<0.30
28	Southville Tank 1 Blk 19 Lot 33	Brgy. Marinig, Cabuyao	1/12/2016	12:40 PM	-	ABSENT	<0.30
29	Southville Tank 4 Blk 45 Deepwell	Brgy. Niugan, Cabuyao	1/12/2016	1:15 PM	<1	ABSENT	<0.30
30	Southville Tank 4 Blk 40 Lot 132	Brgy. Niugan, Cabuyao	1/12/2016	12:59 PM	-	ABSENT	0.45
31	Southville Tank 5 Blk 54 Deepwell	Brgy. Niugan, Cabuyao	1/18/2016	10:38 AM	<1	ABSENT	<0.30
32	Southville Tank 5 Blk 47 Lot 101	Brgy. Niugan, Cabuyao	1/18/2016	11:08 AM	-	ABSENT	<0.30
33	Willow Park, Tank	Brgy. Pulo, Cabuyao	1/18/2016	10:08 AM	<1	ABSENT	<0.30
34	Guardhouse, Willow Park	Brgy. Pulo, Cabuyao	1/18/2016	10:27 AM	-	ABSENT	<0.30
35	Matang Tubig Spring	Brgy. Casile, Cabuyao	1/26/2016	11:36 AM	<1	ABSENT	1.06
36	#253 Elsol Subdivision, Cabuyao City	Brgy. Elsol, Cabuyao	1/13/2016	11:17 AM	-	ABSENT	0.69
37	Wash Area, Niugan Elementary School	Brgy. Niugan, Cabuyao	1/18/2016	11:59 AM	<1	ABSENT	0.97
PNSDW LIMIT					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT
Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026
Telephone Number: (049) 534 1627 - (02) 519 4887

LOCATION (CALAMBA CITY)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
#	Sampling Point	Address					
1	Deepwell 1, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	1/20/2016	12:21 PM	<1	ABSENT	0.50
2	Block 39 Lot 1, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	1/20/2016	11:35 AM	-	ABSENT	0.70
3	Deepwell 2, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	1/20/2016	11:54 AM	<1	ABSENT	0.60
4	Block 23 Lot 31, Amaia Scapes Calamba	Brgy. Barandal, Calamba City	1/20/2016	11:42 AM	-	ABSENT	0.60
PNSDW LIMIT					<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT

Analyst (PRC License No. 0054161)
(NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
Head of the Laboratory

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Company

2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 534 1627 - (02) 519 4887




LAGUNA AAAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
 (JANUARY 2016)

LOCATION (ALAMINOS)			Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/mL)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*
#	Sampling Point	Address					
1	Source, BellaVita Homes	Brgy. San Andres, Alaminos	1/20/2016	2:02 PM	<1	ABSENT	0.53
2	Block 21 Lot 18, BellaVita Homes	Brgy. San Andres, Alaminos	1/20/2016	2:18 PM	-	ABSENT	0.36
PNSDW LIMIT					<500	ABSENT	


Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method
 Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYRIL A. ERICA, RMT
 Analyst (PRC License No. 0054161)
 (NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
 Head of the Laboratory

LAGUNA AAAWATER CORPORATION
 A Joint Venture of the Provincial Government of Laguna and Manila Water Company
 2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026
 Telephone Number: (049) 534 1627 · (02) 519 4887




LAGUNA AAWATER CORPORATION LABORATORY
MONTHLY BACTERIOLOGICAL EXAMINATION OF WATER SAMPLES FROM THE SOURCE & DISTRIBUTION
 (JANUARY 2016)

LOCATION (SANTA CRUZ CITY)		Date of Sampling	Time of Sampling	Heterotrophic Plate Count ¹ (CFU/ml)	Coliform Bacteria ²	Residual Chlorine ³ (mg/L)*		
#	Sampling Point	Address						
1	Deepwell Source (after DMI 65)	San Luis Sports Complex, Sta. Cruz, Laguna		1/28/2016	12:47 PM	<1	ABSENT	0.70
2	Canteen No. 4 in front of the Laguna University Administration Bldg.	San Luis Sports Complex, Sta. Cruz, Laguna		1/28/2016	1:22 PM	-	ABSENT	0.30
PNSDW LIMIT						<500	ABSENT	

Test Methods Used: ¹Pour plate, ²Chromogenic Substrate, ³DPD Colorimetric Method


Legend: *Detection Limit = <0.3 mg/L

Prepared by:



CYBIL A. ERICA, RMT
 Analyst (PRC License No. 0054161)
 (NRL No. WLMA-14-0274)

Certified Correct:



AMPARO C. CAÑAMO
 Head of the Laboratory

LAGUNA AAWATER CORPORATION
 A Joint Venture of the Provincial Government of Laguna and Manila Water Company
 2/F Banawe de Sta. Rosa Building, F. Reyes St., Balibago, Sta. Rosa City, Laguna 4026
 Telephone Number: (049) 534 1627 - (02) 519 4887