

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : BIÑAN	MONTH : SEPTEMBER	YEAR : 2016
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

NO	SAMPLE LOCATION ADDRESS	TYPE	DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
						TOTAL	<i>Escherichia coli</i>
BRGY. BIÑAN							
1	Laguna Well Field 1	Source	9/29/2016	5:10 PM	<1	ABSENCE	ABSENCE
2	Pump 6, Santol St., Phase 4C, San Jose Village I	Source	9/28/2016	5:15 PM	-	ABSENCE	ABSENCE
3	Blk 3 Lot 28, Santol st., Phase 4C, San Jose Village I	Distribution	9/5/2016	10:07 AM	-	ABSENCE	ABSENCE
4	Pump 2, Jacana St., Phase 3B, San Jose Village I	Source	9/28/2016	5:06 PM	3	ABSENCE	ABSENCE
5	Blk 2 Lot 18, Jacana St., Phase 3B, San Jose Village I	Distribution	9/5/2016	10:29 AM	<1	ABSENCE	ABSENCE
6	Pump 11, Phase 5, San Jose Village II	Source	9/28/2016	5:31 PM	-	ABSENCE	ABSENCE
7	Blk 1 Lot 23, Camia St., Phase 5, San Jose Village II	Distribution	9/28/2016	5:24 PM	<1	ABSENCE	ABSENCE
8	Pump 7, San Jose Village III	Source	9/28/2016	5:40 PM	<1	ABSENCE	ABSENCE
9	Clubhouse, Phase 6, San Jose Village III	Distribution	9/5/2016	9:44 AM	-	ABSENCE	ABSENCE
BRGY. CANLALAY							
10	#21 A. Bonifacio St.	Distribution	9/3/2016	5:39 PM	-	ABSENCE	ABSENCE
11	Golden City Canlalay Clubhouse	Distribution	9/23/2016	12:27 PM	-	ABSENCE	ABSENCE
12	Drinking Fountain, Canlalay Elementary School	Distribution	9/29/2016	4:30 PM	-	ABSENCE	ABSENCE
BRGY. DELA PAZ							
13	9028 WP GP Sta. Bernardina St. Kapitana Dela Paz	Source	9/23/2016	9:50 AM	1	ABSENCE	ABSENCE
14	Barangay Hall	Distribution	9/3/2016	4:57 PM	-	ABSENCE	ABSENCE
BRGY. GANADO							
15	Drinking Fountain, Ganado Elementary School	Distribution	9/26/2016	12:33 AM	5	ABSENCE	ABSENCE
BRGY. HALANG							
16	9999 WP Metroville Complex	Source	9/23/2016	12:06 PM	-	ABSENCE	ABSENCE
17	Clubhouse, Metroville Complex	Distribution	9/23/2016	12:16 PM	-	ABSENCE	ABSENCE
BRGY. LANGKIWA							
18	Block 3 Lot 13 Phase 2, Southville Langkiwa	Distribution	9/5/2016	2:51 PM	6	ABSENCE	ABSENCE
19	Block 65 Lot 5 Phase 1, Southville Langkiwa	Distribution	9/5/2016	2:35 PM	-	ABSENCE	ABSENCE
20	Block 20 Lot 7 Phase 2, Southville Langkiwa	Distribution	9/5/2016	2:22 PM	20	ABSENCE	ABSENCE
21	Block 21 Lot 8 Phase 1, Southville Langkiwa	Distribution	9/5/2016	3:05 PM	-	ABSENCE	ABSENCE
22	Block 18 Lot 11 Phase 4, Southville Langkiwa	Distribution	9/5/2016	1:51 PM	-	ABSENCE	ABSENCE
23	Block 31 Lot 27, Phase 3, Southville Langkiwa	Distribution	9/5/2016	2:08 PM	-	ABSENCE	ABSENCE
24	Drinking Fountain, Langkiwa Elementary School	Distribution	9/5/2016	3:19 PM	-	ABSENCE	ABSENCE
BRGY. LOMA							
25	Water Pump, Celina Mansion Subdivision	Source	9/29/2016	4:13 PM	-	ABSENCE	ABSENCE
26	Block 2 Lot 41, Celina Mansion Subdivision	Distribution	9/7/2016	3:48 PM	120	ABSENCE	ABSENCE
27	Water Pump, Block 4 Lot 37, Celina Technopark	Source	9/29/2016	4:07 PM	-	ABSENCE	ABSENCE
28	Block 13 Lot 43, Celina Technopark	Distribution	9/7/2016	3:43 PM	-	ABSENCE	ABSENCE
29	Block 2 Lot 16, Phase 1, Laguna Bel-Air 3	Source	9/13/2016	2:38 PM	-	ABSENCE	ABSENCE
30	Hillcrest Road, Block 2, Laguna Bel-Air 3	Distribution	9/5/2016	12:11 PM	-	ABSENCE	ABSENCE
31	4NR Block 99, Phase 4, Laguna Bel-Air 3	Source	9/13/2016	2:48 PM	-	ABSENCE	ABSENCE
32	Brenna Model House, Phase 1, Laguna Bel-Air 3	Distribution	9/5/2016	12:57 PM	-	ABSENCE	ABSENCE
33	Block 50, Phase 2, Laguna Bel-Air 3	Source	9/13/2016	2:58 PM	4	ABSENCE	ABSENCE
34	Block 6 Lot 66, Laguna Bel-Air 3	Distribution	9/5/2016	12:31 PM	4	ABSENCE	ABSENCE
35	Drinking Fountain, Loma Elementary School	Distribution	9/5/2016	4:00 PM	60	ABSENCE	ABSENCE
BRGY. MALAMIG							
36	Block 5 Lot 16	Distribution	9/7/2016	3:27 PM	91	ABSENCE	ABSENCE
BRGY. MAMPLASAN							

37	Tank, Verdana Homes Subdivision	Source	9/28/2016	5:54 PM	<1	ABSENCE	ABSENCE
38	Clubhouse, Verdana Homes Subdivision	Distribution	9/28/2016	5:59 PM	-	ABSENCE	ABSENCE
39	United Laboratories (UNILAB) Inc.	Distribution	9/26/2016	12:14 PM	94	ABSENCE	ABSENCE
BRGY. POBLACION							
40	9018 WP Public Market 4024 Town Proper	Source	9/26/2016	2:30 PM	430	ABSENCE	ABSENCE
BRGY. PLATERO							
41	Drinking Fountain, St. Michael School of Biñan	Distribution	9/29/2016	3:54 PM	-	ABSENCE	ABSENCE
42	Sea-oil, National Road	Distribution	9/3/2016	2:59 PM	-	ABSENCE	ABSENCE
BRGY. SAN ANTONIO							
43	9022 Water Pump (WP) Faraon Subdivision	Source	9/26/2016	11:13 AM	110	ABSENCE	ABSENCE
44	Block 5 Lot 12, Margarita Homes Subdivision	Distribution	9/3/2016	3:16 PM	-	ABSENCE	ABSENCE
45	Drinking Fountain 1, Faraon Elementary School	Distribution	9/3/2016	4:01 PM	-	ABSENCE	ABSENCE
46	Drinking Fountain 2, Faraon Elementary School	Distribution	9/3/2016	4:08 PM	-	ABSENCE	ABSENCE
47	Cistern Tank, Pavillion Mall	Distribution	9/22/2016	1:56 PM	<1	ABSENCE	ABSENCE
48	Jollibee, Pavillion Mall	Distribution	9/22/2016	2:03 PM	7	ABSENCE	ABSENCE
BRGY. SANTO NIÑO							
49	Jollibee National Hi-Way	Distribution	9/22/2016	2:03 PM	-	ABSENCE	ABSENCE
BRGY. SAN VICENTE							
50	9001 GP San Vicente	Source	9/23/2016	11:17 AM	-	ABSENCE	ABSENCE
51	B8 L6, Bayabas St., Olivarez 7	Distribution	9/23/2016	11:06 AM	-	ABSENCE	ABSENCE
52	Cistern Tank, Central Mall	Distribution	9/22/2016	1:31 PM	<1	ABSENCE	ABSENCE
53	Drinking Fountain, San Vicente Elementary Sch.	Distribution	9/23/2016	3:59 PM	-	ABSENCE	ABSENCE
BRGY. SANTO TOMAS							
54	Gate Entrance, Adelina Complex III Subdivision	Distribution	9/29/2016	4:10 PM	-	ABSENCE	ABSENCE
55	1 LT Water Pump, Phase 1B, Olivarez Homes South	Source	9/23/2016	9:35 AM	-	ABSENCE	ABSENCE
56	Block 1 Lot 26, Phase 3, Olivarez Homes South	Distribution	9/23/2016	9:40 AM	-	ABSENCE	ABSENCE
57	5555 Block 1, Phase 4, Olivarez Homes South	Source	9/23/2016	9:08 AM	-	ABSENCE	ABSENCE
58	Block 2 ot 9, Phase 4, Olivarez Homes South	Distribution	9/23/2016	9:15 AM	-	ABSENCE	ABSENCE
59	Pump House, Kalibo St., South City Homes	Source	9/23/2016	10:06 AM	-	ABSENCE	ABSENCE
60	Block 76 Lot 6, Tangub St., Pragmatic	Distribution	9/23/2016	10:18 AM	-	ABSENCE	ABSENCE
61	Pump, South Plains II Subdivision	Source	9/23/2016	10:25 AM	<1	ABSENCE	ABSENCE
62	Block 11 Lot 2, South Plains II Subdivision	Distribution	9/23/2016	10:30 AM	-	ABSENCE	ABSENCE
63	Pump, Amsterdam St., Phase 2, Town & Country	Source	9/23/2016	8:31 AM	-	ABSENCE	ABSENCE
64	Block 35 Lot 21, Town & Country	Distribution	9/23/2016	8:36 AM	-	ABSENCE	ABSENCE
65	Block 2 Lot 5, Town & Country	Distribution	9/23/2016	4:20 PM	-	ABSENCE	ABSENCE
BRGY. SORO - SORO							
66	9067 Soro-soro	Source	9/23/2016	11:43 AM	-	ABSENCE	ABSENCE
67	#76 Soro-Soro	Distribution	9/23/2016	11:48 AM	-	ABSENCE	ABSENCE
BRGY. TUBIGAN							
68	#60 Forinda Compound	Distribution	9/23/2016	11:33 AM	-	ABSENCE	ABSENCE
BRGY. ZAPOTE							
69	Water Pump, Althea	Source	9/23/2016	10:44 AM	-	ABSENCE	ABSENCE
70	Model House, Block 6, Althea	Distribution	9/23/2016	1:00 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		70	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES :³Philippine National Standard for Drinking Water, 2007

:⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT

Analyst (License No. 0054161)

CERTIFIED CORRECT



AMPARO C. CAÑAMO

Head of Laboratory

DATE/TIME

10/04/2016 5:00 PM

DATE/TIME

10/5/16 9:10 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : SANTA ROSA	MONTH : SEPTEMBER	YEAR : 2016
DOH ACCREDITATION NO. : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

NO	ADDRESS	TYPE	DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
						TOTAL	<i>Escherichia coli</i>
BRGY. BALIBAGO							
1	#1354 Facundo Compound	Distribution	9/6/2016	2:13 PM	-	ABSENCE	ABSENCE
2	5555 Water Pump Elevated, South Hampton	Source	9/15/2016	9:20 AM	-	ABSENCE	ABSENCE
3	Block 1 Lot 5, South Hampton	Distribution	9/5/2016	6:04 PM	80	ABSENCE	ABSENCE
4	Block 11 Lot 2, JB Village, Sta. Rosa Tagaytay Road	Distribution	9/27/2016	1:42 PM	-	ABSENCE	ABSENCE
5	Cistern Tank, Waltermart Sta. Rosa	Distribution	9/23/2016	12:38 PM	-	ABSENCE	ABSENCE
6	3rd Floor Faucet, Waltermart Sta. Rosa	Distribution	9/23/2016	12:27 PM	-	ABSENCE	ABSENCE
BRGY. CAINGIN							
7	9002 Block 53, Phase 4, Southville	Source	9/26/2016	3:12 PM	2	ABSENCE	ABSENCE
8	Block 52 Lot 23, Phase 1, Southville	Distribution	9/6/2016	1:52 PM	<1	ABSENCE	ABSENCE
BRGY. DILA							
9	Phase 3E, Mabuhay Homes 2000	Source	9/26/2016	3:10 PM	1	ABSENCE	ABSENCE
10	Block 2 Lot 10, Mabuhay Homes 2000	Distribution	9/26/2016	3:20 PM	4	ABSENCE	ABSENCE
11	Block 12, Phase 2E, Mabuhay Homes 2000	Source	9/26/2016	3:29PM	<1	ABSENCE	ABSENCE
12	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	Distribution	9/26/2016	3:35 PM	<1	ABSENCE	ABSENCE
13	Drinking Fountain, Dila Elementary School	Distribution	9/30/2016	8:10 AM	-	ABSENCE	ABSENCE
BRGY. DITA							
14	Block 24 Lot 2, New Santa Rosa Homes	Source	9/26/2016	3:40 PM	30	ABSENCE	ABSENCE
15	Block 19 Lot 11, New Santa Rosa Homes	Distribution	9/26/2016	3:45 PM	63	ABSENCE	ABSENCE
16	Block 4 Lot 32, San Lorenzo Royale	Source	9/23/2016	1:32 PM	-	ABSENCE	ABSENCE
17	Block 11 Lot 52, San Lorenzo Royale	Distribution	9/5/2016	5:38 PM	-	ABSENCE	ABSENCE
18	Water Tank, SolCar Ville Subdivision	Source	9/27/2016	9:50 AM	<1	ABSENCE	ABSENCE
19	Block 3 Lot 7, SolCar Ville Subdivision	Distribution	9/27/2016	10:10 AM	-	ABSENCE	ABSENCE
20	Water Tank, Villa Esmeralda	Source	9/23/2016	1:24 PM	-	ABSENCE	ABSENCE
21	Alabaster St., Villa Esmeralda	Distribution	9/5/2016	5:38 PM	-	ABSENCE	ABSENCE
22	#1780 National Road	Distribution	9/30/2016	8:19 AM	-	ABSENCE	ABSENCE
23	Lima Express Ice Plant, Inc.	Distribution	9/22/2016	12:18 PM	<1	ABSENCE	ABSENCE
BRGY. DON JOSE							
24	Block 7 Lot 62, Phase 3, Laguna Bel-Air	Source	9/13/2016	3:21 PM	-	ABSENCE	ABSENCE
25	Science HighSchool, Phase 1, Laguna Bel-Air	Distribution	9/5/2016	2:12 PM	<1	ABSENCE	ABSENCE
26	Block 34 Lot 14, Phase 1, Laguna Bel-Air	Source	9/13/2016	3:08 PM	-	ABSENCE	ABSENCE
27	Block 34 Lot 59, Phase 1, Laguna Bel-Air	Distribution	9/5/2016	1:10 PM	-	ABSENCE	ABSENCE
28	Clubhouse, Block 62, Laguna Bel-Air	Distribution	9/5/2016	2:36 PM	240	ABSENCE	ABSENCE
29	Water Pump, Block 71, Phase 4, Laguna Bel-Air	Source	9/13/2016	2:13 PM	-	ABSENCE	ABSENCE
30	Block 71 Lot 4, Phase 2, Laguna Bel-Air	Distribution	9/5/2016	11:35 AM	-	ABSENCE	ABSENCE
31	Block 108, Phase 5, Laguna Bel-Air	Source	9/13/2016	1:57 PM	11	ABSENCE	ABSENCE
32	Church, Block 108, Phase 2, Laguna Bel-Air	Distribution	9/5/2016	10:45 AM	<1	ABSENCE	ABSENCE
33	1NR Block 43, Laguna Bel-Air IV	Source	9/13/2016	3:30 PM	<1	ABSENCE	ABSENCE
34	Block 47 Lot 12 Laguna Bel-Air IV	Distribution	9/30/2016	9:00 AM	-	ABSENCE	ABSENCE
35	8001, Pump 1, Acacia St., Santa Rosa Village I	Source	9/28/2016	4:52 PM	16	ABSENCE	ABSENCE
36	Clubhouse., Santa Rosa Village I	Distribution	9/5/2016	10:43 AM	-	ABSENCE	ABSENCE
37	Pump 9 & 10, Rembrandt St., Santa Rosa Estates I	Source	9/28/2016	4:46 PM	-	ABSENCE	ABSENCE
38	101 Elde France St., Phase 4A, Santa Rosa Village II	Distribution	9/5/2016	11:00 AM	<1	ABSENCE	ABSENCE
39	Clubhouse, Santa Rosa Estates I	Distribution	9/5/2016	11:14 AM	<1	ABSENCE	ABSENCE
40	Reservoir, Hacienda Sta. Elena	Distribution	9/26/2016	11:35 AM	<1	ABSENCE	ABSENCE

BRGY. KANLURAN							
41	Malusak Bakery, #621 Rizal Boulevard	Distribution	9/6/2016	9:16 AM	73	ABSENCE	ABSENCE
BRGY. MACABLING							
42	Deepwell, Buena Rosa 9 Subdivision	Source	9/27/2016	1:07 PM	-	ABSENCE	ABSENCE
43	Block 11 Lot 9, Phase 2, Buena Rosa 9 Subdivision	Distribution	9/4/2016	2:25 PM	-	ABSENCE	ABSENCE
44	Deepwell, Corinthian Subdivision	Source	9/27/2016	1:25 PM	-	ABSENCE	ABSENCE
45	Block 11 Lot 19, Corinthian Subdivision	Distribution	9/4/2016	1:06 PM	-	ABSENCE	ABSENCE
46	Deepwell, Rosemont Subdivision	Source	9/27/2016	12:52 PM	-	ABSENCE	ABSENCE
47	Block 3 Lot 22, Rosemont Subdivision	Distribution	9/4/2016	2:44 PM	-	ABSENCE	ABSENCE
48	Block 4 Lot 3, Rosa Subdivision	Distribution	9/4/2016	12:19 PM	-	ABSENCE	ABSENCE
BRGY. MALITLIT							
49	Water Pump, Casan Residencia Subdivision	Source	9/27/2016	10:15 AM	-	ABSENCE	ABSENCE
50	Block 1 Lot 4, Casan Residencia Subdivision	Distribution	9/27/2016	10:20 AM	-	ABSENCE	ABSENCE
51	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	Source	9/23/2016	1:32 PM	-	ABSENCE	ABSENCE
52	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	Distribution	9/5/2016	3:45 PM	-	ABSENCE	ABSENCE
53	Main Road, Phase 2, Terra Fortuna	Source	9/23/2016	1:16 PM	-	ABSENCE	ABSENCE
54	Block 11 Lot 16, Terra Fortuna	Distribution	9/5/2016	4:55 PM	110	ABSENCE	ABSENCE
55	9999 W, Villa Las Casas	Source	9/23/2016	1:05 PM	-	ABSENCE	ABSENCE
56	Block 1 Lot 17, Villa Las Casas	Distribution	9/5/2016	4:37 PM	-	ABSENCE	ABSENCE
BRGY. MALUSAK							
57	Drinking Fountain 1, Central 1 Elementary Sch.	Distribution	9/26/2016	1:48 PM	<1	ABSENCE	ABSENCE
58	Drinking Fountain 2, Central 1 Elementary Sch.	Distribution	9/26/2016	1:55 PM	<1	ABSENCE	ABSENCE
BRGY. MARKET AREA							
60	Source, Market Area	Source	9/26/2016	9:25 AM	28	ABSENCE	ABSENCE
61	Block 9 Lot 2, Terry Town West	Distribution	9/6/2016	9:31 AM	-	ABSENCE	ABSENCE
BRGY. POOC							
62	Deepwell, Alinsod	Source	9/27/2016	11:02 AM	-	ABSENCE	ABSENCE
63	Block 1 Lot 34, Phase 5, Southville	Distribution	9/6/2016	12:22 PM	73	ABSENCE	ABSENCE
BRGY. PULONG SANTA CRUZ							
64	Water Pump, Pulong Sta. Cruz	Source	9/15/2016	9:52 AM	-	ABSENCE	ABSENCE
65	Block 7 Lot 3, Mercado Village	Distribution	9/27/2016	1:54 PM	<1	ABSENCE	ABSENCE
66	Block 6 Lot 8, Buklod Diwa	Distribution	9/26/2016	12:23 PM	<1	ABSENCE	ABSENCE
BRGY. SINALHAN							
67	Block 5 Lot 7, Phase 1, Bayshore I	Distribution	9/6/2016	10:11 AM	25	ABSENCE	ABSENCE
68	Block 6 Lot 16, Bayshore II	Distribution	9/6/2016	9:56 AM	-	ABSENCE	ABSENCE
69	4026, Sinalhan Road, Purok 2	Source	9/26/2016	1:37 PM	<1	ABSENCE	ABSENCE
70	Amoranto Compound, Phase 2, Sinalhan	Distribution	9/6/2016	10:30 AM	<1	ABSENCE	ABSENCE
BRGY. STO. DOMINGO							
71	Laguna Water Head Office, One Evotech Bldg.	Distribution	9/30/2016	9:30 AM	<1	ABSENCE	ABSENCE
72	Clubhouse Santa Rosa Estates II	Distribution	9/5/2016	11:23 AM	-	ABSENCE	ABSENCE
BRGY. TAGAPO							
73	Water Pump, Fairfield of Margana Subdivision	Source	9/26/2016	1:08 PM	-	ABSENCE	ABSENCE
74	Block 7 Lot 15, Fairfield of Margana Subdivision	Distribution	9/6/2016	11:24 AM	-	ABSENCE	ABSENCE
75	Water Pump, Metrogate	Source	9/27/2016	12:02 PM	110	ABSENCE	ABSENCE
76	Water Pump, Rosewood Homes I	Source	9/15/2016	8:37 AM	-	ABSENCE	ABSENCE
77	Block 4 Lot 10, Rosewood Homes I	Distribution	9/4/2016	4:26 PM	-	ABSENCE	ABSENCE
78	Block 4 Lot 8, Rosewood Homes II	Distribution	9/27/2016	11:42 AM	<1	ABSENCE	ABSENCE
79	#31 JP Rizal Boulevard	Distribution	9/27/2016	12:28 PM	-	ABSENCE	ABSENCE
80	Water Pump, Buena Rosa 1 Subdivision	Source	9/27/2016	12:15 PM	-	ABSENCE	ABSENCE
81	Guardhouse, Buena Rosa 1 Subdivision	Distribution	9/27/2016	12:22 PM	-	ABSENCE	ABSENCE
82	Water Pump, Buena Rosa 10 Subdivision	Distribution	9/15/2016	7:41 AM	-	ABSENCE	ABSENCE
83	Block 1 Lot 26, Buena Rosa 10 Subdivision	Distribution	9/4/2016	5:02 PM	-	ABSENCE	ABSENCE
84	Cistern Tank, SM Sta. Rosa	Distribution	9/22/2016	2:53 PM	<1	ABSENCE	ABSENCE
85	Crepes Delicious, SM Sta. Rosa	Distribution	9/22/2016	2:59 PM	3	ABSENCE	ABSENCE
86	Cistern Tank, Robinson's Mall	Distribution	9/22/2016	2:31 PM	<1	ABSENCE	ABSENCE

87	Chummie Shawarma, Robinson's Mall	Distribution	9/22/2016	2:36 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		87	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY




CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

DATE/TIME

_____ 10/04/2016 5:00 PM

CERTIFIED CORRECT



AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

_____ 10/19/16 9:35 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

CITY/MUNICIPALITY : CABUYAO		MONTH : AUGUST		YEAR : 2016			
DOH ACCREDITATION NO : 04A-010-16-LW-2		VALIDITY : December 31, 2018					
NO	ADDRESS	TYPE	DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
						TOTAL	<i>Escherichia coli</i>
BRGY. BANAY-BANAY							
1	Water Pump, Block 63, Lakeside Nest Subdivision	Source	9/27/2016	1:34 PM	<1	ABSENCE	ABSENCE
2	Block 12 Lot 15, Lakeside Nest Subdivision	Distribution	9/6/2016	3:33 PM	-	ABSENCE	ABSENCE
BRGY. BANLIC							
3	Water Pump, Gran Seville Subdivision	Source	9/27/2016	9:12 AM	-	ABSENCE	ABSENCE
4	Guardhouse, Gran Seville Subdivision	Distribution	9/27/2016	9:24 AM	-	ABSENCE	ABSENCE
BRGY. BIGAA							
5	#253 Elsol Subdivision	Distribution	9/26/2016	1:10 PM	<1	ABSENCE	ABSENCE
BRGY. CASILE							
6	Matang Tubig Spring	Source	9/26/2016	12:30 PM	<1	ABSENCE	ABSENCE
BRGY. GULOD							
7	Block 12, Noah St., Celestine Ville	Source	9/19/2016	11:47 AM	-	ABSENCE	ABSENCE
8	Block 3 Lot 1, Celestine Ville Ave., Celestine Ville	Distribution	9/6/2016	2:46 PM	-	ABSENCE	ABSENCE
BRGY. MAMATID							
9	Tank, Buena Rosario Subdivision	Source	9/19/2016	10:54 AM	-	ABSENCE	ABSENCE
10	Block 7 Lot 6, Buena Rosario Subdivision	Distribution	9/6/2016	12:11 PM	-	ABSENCE	ABSENCE
11	Block 101 Samar st., Phase 2, Mabuhay City	Source	9/19/2016	11:10 AM	77	ABSENCE	ABSENCE
12	Block 94 Lot 34, Guimaras St., Phase 1, Mabuhay City	Distribution	9/6/2016	1:18 PM	-	ABSENCE	ABSENCE
13	Block 141, Carmona St., Phase 2, Mabuhay City	Source	9/19/2016	11:32 AM	15	ABSENCE	ABSENCE
14	Block 134 Lot 22, Phase 2, Mabuhay City	Distribution	9/6/2016	1:40 PM	-	ABSENCE	ABSENCE
15	Block 198, Galacia St., Phase 2, Mabuhay City	Source	9/19/2016	11:21 AM	-	ABSENCE	ABSENCE
16	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay	Distribution	9/6/2016	1:40 PM	-	ABSENCE	ABSENCE
17	Panganig St., Phase 3 Cluster, Mabuhay City	Source	9/19/2016	12:00 NN	3	ABSENCE	ABSENCE
18	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	Distribution	9/6/2016	11:05 AM	<1	ABSENCE	ABSENCE
19	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	Source	9/19/2016	12:11 PM	-	ABSENCE	ABSENCE
20	Block 19 Lot 13, Malang St., Phase 3 Luxury, Mabuhay	Distribution	9/6/2016	11:34 AM	<1	ABSENCE	ABSENCE
21	Joshua St., Phase 5, Mabuhay City	Source	9/19/2016	12:22 PM	-	ABSENCE	ABSENCE
22	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	Distribution	9/6/2016	10:50 AM	68	ABSENCE	ABSENCE
BRGY. MARINIG							
23	Block 3 Lot 17, Phase 1, Celestine Homes	Source	9/26/2016	2:20 PM	<1	ABSENCE	ABSENCE
24	Block 7, Lot 16, Phase 1, Celestine Homes	Distribution	9/27/2016	3:00 PM	-	ABSENCE	ABSENCE
25	Block 9, Carnation St., Phase 2, Celestine Homes	Source	9/26/2016	2:50 PM	<1	ABSENCE	ABSENCE
26	Block 23 Lot 10, Phase 2, Celestine Homes	Distribution	9/27/2016	2:45 PM	1	ABSENCE	ABSENCE
27	Block 25, Phase 3, Southville	Source	9/27/2016	2:30 PM	-	ABSENCE	ABSENCE
28	Block 19 Lot 33, Phase 3, Southville	Distribution	9/27/2016	2:20 PM	<1	ABSENCE	ABSENCE
BRGY. NIUGAN							
29	Water Pump, Niugan Elementary School Compound	Source	9/8/2016	7:37 AM	<1	ABSENCE	ABSENCE
30	Block 6 Lot 2, St. Francis Homes 6	Distribution	9/8/2016	7:20 AM	<1	ABSENCE	ABSENCE
31	Block 45, Phase 8, Southville	Source	9/27/2016	1:34 PM	-	ABSENCE	ABSENCE
32	Block 40 Lot 132, Southville	Distribution	9/27/2016	2:10 PM	<1	ABSENCE	ABSENCE
33	Block 54, Phase 10, Southville	Source	9/27/2016	1:45 PM	-	ABSENCE	ABSENCE
34	Block 473 Lot 101, Phase 10, Southville	Distribution	9/27/2016	4:03 PM	-	ABSENCE	ABSENCE
BRGY. PULO							
35	Block 12 Lot 22, Cabuyao Central	Source	9/8/2016	8:33 AM	<1	ABSENCE	ABSENCE
36	Clubhouse, Narra Avenue, Cabuyao Central	Distribution	9/8/2016	8:44 AM	<1	ABSENCE	ABSENCE

37	Block 11, Willow Park Homes	Source	9/8/2016	8:00 AM	<1	ABSENCE	ABSENCE
38	Guardhouse, Main St., Willow Park Homes	Distribution	9/8/2016	8:10 AM	<1	ABSENCE	ABSENCE
BRGY. SALA							
39	Guardhouse, Main St., Multiland III	Distribution	9/27/2016	10:33 AM	3	ABSENCE	ABSENCE
BRGY. SAN ISIDRO							
40	Source, Multiland IV	Source	9/19/2016	10:32 AM	7	ABSENCE	ABSENCE
41	Block 2 Lot 16B, Multiland IV	Distribution	9/6/2016	9:48 AM	<1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		41	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY



CYRIL A. ERICA, RMT

Analyst (License No. 0054161)

DATE/TIME

10/04/2016 5:00PM

CERTIFIED CORRECT



AMPARO C. CAÑAMO

Head of Laboratory

DATE/TIME

10/5/16 9:15 A.M.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY	: CALAMBA	MONTH	: SEPTEMBER	YEAR	: 2016	
DOH ACCREDITATION NO	: 04A-010-16-LW-2	VALIDITY	: December 31, 2018			

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BARANDAL							
1	Deepwell 1, Amaia Scapes Calamba	Source	9/27/2016	4:35 PM	<1	ABSENCE	ABSENCE
2	Block 39 Lot 1, Amaia Scapes Calamba	Distribution	9/27/2016	4:44 PM	-	ABSENCE	ABSENCE
3	Deepwell 3, Amaia Scapes Calamba	Source	9/27/2016	4:50 PM	23	ABSENCE	ABSENCE
4	Guardhouse, Amaia Scapes Calamba	Distribution	9/27/2016	5:20 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		4	2007 PNSDW LIMIT ³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ : ¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES : ³Philippine National Standard for Drinking Water, 2007
: ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition


PREPARED BY


CYRIL A. ERICA, RMT
Analyst (License No. 0054161)

DATE/TIME

10/04/2016 5:00pm

CERTIFIED CORRECT


AMPARO C. CAÑAMO
Head of Laboratory

DATE/TIME

10/5/16 9:18 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company

G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026

Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007



LAGUNA AAAWATER CORPORATION
 OPERATIONS DEPARTMENT
 LABORATORY SERVICES
MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY : ALAMINOS	MONTH : SEPTEMBER	YEAR : 2016
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	

SAMPLE LOCATION			DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
NO	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. SAN ANDRES							
1	Water Tank, Bellavita Homes	Source	9/27/2016	3:24 PM	100	ABSENCE	ABSENCE
2	Block 8 Lot 1, Phase 1, BellaVita Homes	Distribution	9/27/2016	3:47 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)
 REFERENCES : ³Philippine National Standard for Drinking Water, 2007
 : ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition

PREPARED BY

CYRIL A. ERICA, RMT
 Analyst (License No. 0054161)

CERTIFIED CORRECT

AMPARO C. CAÑAMO
 Head of Laboratory

DATE/TIME

10/04/2016 5:00pm

DATE/TIME

10/5/16 9:20a.m.

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES

MICROBIOLOGICAL EXAMINATION OF WATER SAMPLES FROM SOURCE AND DISTRIBUTION

CITY/MUNICIPALITY :	SANTA CRUZ	MONTH :	SEPTEMBER	YEAR :	2016
DOH ACCREDITATION NO :	04A-010-16-LW-2	VALIDITY :	December 31, 2018		

NO	SAMPLE LOCATION		DATE OF SAMPLING	TIME OF SAMPLING	Heterotrophic Plate Count ¹ (in CFU/mL)	COLIFORMS/100 mL ²	
	ADDRESS	TYPE				TOTAL	<i>Escherichia coli</i>
BRGY. BUBUKAL							
1	Source after Filter, Laguna Sports Complex	Source	9/27/2016	1:46 PM	78	ABSENCE	ABSENCE
2	Canteen No. 4 in front of Laguna University	Distribution	9/27/2016	1:56 PM	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	2007 PNSDW LIMIT³		<500	ABSENCE	ABSENCE

NOTES

TEST METHODS USED⁴ :¹Pour Plate, ²Enzyme Substrate (Colilert®-18)

REFERENCES : ³Philippine National Standard for Drinking Water, 2007

: ⁴Standard Methods for the Examination of Water and Waste Water, 22nd Edition


PREPARED BY


CYRIL A. ERICA, RMT
Analyst (License No. 0054161)

DATE/TIME

10/04/2016 5:00pm

CERTIFIED CORRECT


AMPARO C. CAÑAMO
Head of Laboratory

DATE/TIME

10/5/16 9:18 a.m.

LAGUNA AAAWATER CORPORATION

A Joint Venture of the Provincial Government of Laguna and Manila Water Philippine Ventures Company
G/F, One Evotech Bldg., Lakeside Evozone, Brgy Sto. Domingo, Sta. Rosa City, Laguna 4026
Telephone Number: (049) 544 4386 loc 1007 · (02) 519 4429 loc 1007