

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : BIÑAN	MONTH : AUGUST	YEAR : 2017
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-08-BIN

NO	SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY	
	ADDRESS	TYPE	***Res. Chlorine ¹ mg/L		Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷	
										TOTAL	<i>Escherichia coli</i>
BRGY. BIÑAN											
1	Laguna Well Field 1	S	23-Aug	0.62	-	0.15	7.4	-	-	ABSENCE	ABSENCE
2	Pump 6, Santol St., Phase 4C, San Jose Village I	S	23-Aug	0.85	-	0.27	7.37	-	-	ABSENCE	ABSENCE
3	Guardhouse Entrance, Phase 4C, San Jose Village I	D	23-Aug	0.48	-	1.07	7.34	-	14	ABSENCE	ABSENCE
4	Clubhouse, Phase 3B, San Jose Village I	D	23-Aug	0.46	-	0.12	7.36	-	-	ABSENCE	ABSENCE
5	Clubhouse, Phase 5, San Jose Village II	D	23-Aug	0.63	-	0.36	7.29	-	< 1	ABSENCE	ABSENCE
6	Clubhouse, Phase 6, San Jose Village III	D	23-Aug	0.67	-	0.03	7.36	-	-	ABSENCE	ABSENCE
BRGY. CANLALAY											
7	#132 A. Bonifacio St.	D	24-Aug	< 0.20	-	0.22	7.91	-	-	ABSENCE	ABSENCE
8	Golden City Canlalay Clubhouse	D	24-Aug	0.91	-	< 0.02	8.01	-	< 1	ABSENCE	ABSENCE
9	Canlalay Elementary School	D	24-Aug	0.77	-	< 0.02	8.03	-	-	ABSENCE	ABSENCE
BRGY. DELA PAZ											
10	Almeda	S	24-Aug	1.02	-	< 0.02	8.04	-	-	ABSENCE	ABSENCE
11	Barangay Hall	D	24-Aug	0.76	-	0.08	8.03	-	< 1	ABSENCE	ABSENCE
BRGY. GANADO											
12	Drinking Fountain, Ganado Elementary School	D	8-Aug	0.69	-	< 0.02	7.59	-	-	ABSENCE	ABSENCE
BRGY. HALANG											
13	9999 WP Metroville Complex	S	24-Aug	1.02	< 2	< 0.02	8.14	**unobjectionable	-	ABSENCE	ABSENCE
14	Clubhouse, Metroville Complex	D	24-Aug	0.63	-	< 0.02	7.96	-	-	ABSENCE	ABSENCE
BRGY. LANGKIWA											
15	Block 3 Lot 9 Phase 2, Southville Langkiwa	D	29-Aug	0.28	-	< 0.02	6.81	-	-	ABSENCE	ABSENCE
16	Block 65 Lot 5 Phase 1, Southville Langkiwa	D	29-Aug	0.48	-	0.04	6.71	-	5	ABSENCE	ABSENCE
17	Block 20 Lot 7 Phase 3, Southville Langkiwa	D	29-Aug	0.37	-	0.03	6.82	-	-	ABSENCE	ABSENCE
18	Block 26 Lot 8 Phase 1, Southville Langkiwa	D	29-Aug	0.62	-	0.06	6.95	-	-	ABSENCE	ABSENCE
19	Block 18 Lot 11 Phase 4, Southville Langkiwa	D	29-Aug	0.50	-	< 0.02	6.78	-	21	ABSENCE	ABSENCE
20	Block 31 Lot 27, Phase 3, Southville Langkiwa	D	29-Aug	0.48	-	< 0.02	6.79	-	-	ABSENCE	ABSENCE
21	Drinking Fountain, Langkiwa Elementary School	D	29-Aug	7.05	-	0.70	7.05	-	-	ABSENCE	ABSENCE

BRGY. LOMA											
22	Water Pump, Celina Mansion Subdivision	S	23-Aug	< 0.20	-	0.30	7.53	-	-	ABSENCE	ABSENCE
23	Block 1 Lot 7, Celina Mansion Subdivision	D	23-Aug	< 0.20	-	0.10	7.30	-	-	ABSENCE	ABSENCE
24	Water Pump, Block 4 Lot 37, Celina Technopark	S	23-Aug	< 0.20	-	0.29	7.54	-	< 1	ABSENCE	ABSENCE
25	Block 7 Lot 2, Celina Technopark	D	23-Aug	< 0.20	-	0.18	7.27	-	-	ABSENCE	ABSENCE
26	Block 8, Laguna Bel-Air 3	S	17-Aug	0.73	-	< 0.02	7.74	-	-	ABSENCE	ABSENCE
27	Brenna Model House, Block 90 Lot 5, Laguna Bel-Air 3	D	17-Aug	0.68	-	< 0.02	7.56	-	-	ABSENCE	ABSENCE
28	Block 2, Phase 4, Laguna Bel-Air 3	S	17-Aug	0.49	-	< 0.02	7.68	-	3	ABSENCE	ABSENCE
29	Hilcrest Road, Block 2, Laguna Bel-Air 3	D	17-Aug	0.48	-	< 0.02	7.60	-	-	ABSENCE	ABSENCE
30	Block 50, Phase 2, Laguna Bel-Air 3	S	17-Aug	0.81	-	0.29	7.61	-	-	ABSENCE	ABSENCE
31	Clubhouse, Laguna Bel-Air 3	D	17-Aug	0.58	-	< 0.20	7.60	-	-	ABSENCE	ABSENCE
32	Drinking Fountain, Loma Elementary School	D	23-Aug	0.65	-	0.11	7.59	-	< 1	ABSENCE	ABSENCE
BRGY. MALAMIG											
33	Block 5 Lot 16	D	23-Aug	0.58	-	0.11	7.45	-	-	ABSENCE	ABSENCE
BRGY. MAMPLASAN											
34	Tank, Verdana Homes Subdivision	S	23-Aug	2.81	-	< 0.02	7.54	-	< 1	ABSENCE	ABSENCE
35	Clubhouse, Verdana Homes Subdivision	D	23-Aug	1.64	-	0.15	7.75	-	< 1	ABSENCE	ABSENCE
36	United Laboratories (UNILAB) Inc.	D	8-Aug	0.56	-	< 0.02	7.91	-	< 1	ABSENCE	ABSENCE
BRGY. POBLACION											
37	Brgy. Hall	S	24-Aug	0.40	-	0.13	8.21	-	-	ABSENCE	ABSENCE
BRGY. PLATERO											
38	Drinking Fountain, St. Michael School of Biñan	D	8-Aug	0.66	-	< 0.02	7.66	-	< 1	ABSENCE	ABSENCE
39	Sea-oil, National Road	D	8-Aug	0.50	-	0.09	7.32	-	< 1	ABSENCE	ABSENCE
BRGY. SAN ANTONIO											
40	Biñan City Hall	S	8-Aug	< 0.20	-	< 0.02	7.55	-	-	ABSENCE	ABSENCE
41	Alonte Stadium	D	8-Aug	0.38	-	< 0.02	7.58	-	53	ABSENCE	ABSENCE
42	9022 Water Pump (WP) Faraon Subdivision	S	24-Aug	1.21	< 2	0.11	8.06	**unobjectionable	-	ABSENCE	ABSENCE
43	Brgy. Hall, Faraon	D	24-Aug	1..10	-	< 0.02	8.01	-	28	ABSENCE	ABSENCE
44	Drinking Fountain 1, Faraon Elementary School	D	24-Aug	0.98	-	< 0.02	8.28	-	-	ABSENCE	ABSENCE
45	Drinking Fountain 2, Faraon Elementary School	D	24-Aug	1.15	-	< 0.02	8.03	-	-	ABSENCE	ABSENCE
46	Cistern Tank, Pavillion Mall	D	17-Aug	0.60	-	0.08	7.95	-	-	ABSENCE	ABSENCE
47	Chop Stop, Pavillion Mall	D	17-Aug	0.53	-	0.04	7.81	-	-	ABSENCE	ABSENCE
BRGY. SANTO NIÑO											
48	Jollibee National Hi-Way	D	17-Aug	0.61	-	0.18	7.76	-	-	ABSENCE	ABSENCE
BRGY. SAN VICENTE											
50	407 San Vicente	S	24-Aug	0.61	-	< 0.02	8.01	-	-	ABSENCE	ABSENCE
51	B8 L6, Bayabas St., Olivarez 7	D	24-Aug	0.84	-	< 0.02	8.06	-	-	ABSENCE	ABSENCE
52	Biñan Doctors Hospital	D	8-Aug	0.65	-	0.10	7.40	-	-	ABSENCE	ABSENCE
53	Drinking Fountain, San Vicente Elementary Sch.	D	24-Aug	0.56	-	< 0.02	8.08	-	-	ABSENCE	ABSENCE

BRGY. SANTO TOMAS											
54	Gate Entrance, Adelina Complex III Subdivision	D	29-Aug	0.52	-	0.11	7.15	-	-	ABSENCE	ABSENCE
55	Block 2 Lot 40, Phase 1B, Olivarez Homes South	D	23-Aug	0.60	-	< 0.02	7.41	-	2	ABSENCE	ABSENCE
56	5555 Block 1, Phase 4, Olivarez Homes South	S								ABSENCE	ABSENCE
58	Pump House, Kalibo St., South City Homes	S	24-Aug	0.63	-	0.11	7.55	-	-	ABSENCE	ABSENCE
59	Block 76 Lot 6, Tangub St., Pragmatic	D	24-Aug	< 0.20	-	0.09	7.65	-	-	ABSENCE	ABSENCE
60	Block 5 Lot 2, South City Homes	D	29-Aug	0.58	-	0.28	7.21	-	-	ABSENCE	ABSENCE
61	Deepwell 3, Phase XI, South City Homes	S	29-Aug	1.14	-	0.36	7.18	-	-	ABSENCE	ABSENCE
62	Tawi Tawi St., Phase 6, South City Homes	D	29-Aug	0.51	-	0.25	7.27	-	-	ABSENCE	ABSENCE
63	Pump, South Plains II Subdivision	S	24-Aug	0.68	-	< 0.02	7.65	-	-	ABSENCE	ABSENCE
65	Pump, Amsterdam St., Phase 2, Town & Country	S	23-Aug	0.28	-	0.03	7.95	-	< 1	ABSENCE	ABSENCE
66	Block 35 Lot 21, Town & Country	D	23-Aug	0.26	-	0.13	7.77	-	< 1	ABSENCE	ABSENCE
67	Block 2 Lot 5, Town & Country - Pennsylvania	D	23-Aug	0.62	-	0.04	7.77	-	81	ABSENCE	ABSENCE
BRGY. SORO - SORO											
68	9067 Soro-soro	S	24-Aug	1.28	-	< 0.02	7.87	-	-	ABSENCE	ABSENCE
69	#76 Soro-Soro	D	24-Aug	1.55	-	< 0.20	7.77	-	-	ABSENCE	ABSENCE
BRGY. TUBIGAN											
70	#60 Florinda Compound	D	24-Aug	0.67	-	< 0.02	8.02	-	6	ABSENCE	ABSENCE
BRGY. ZAPOTE											
71	Block 6 Lot 4, Althea	D	24-Aug	< 0.20	-	< 0.02	7.63	-	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		71	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:



JOVEN M. MARAVILLA
Analytical Laboratory Head
PRC License No. 0012740

NOTED BY:



CYRIL A. ERICA
Laboratory Services Manager
PRC License No. 0054161

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : SANTA ROSA	MONTH : AUGUST	YEAR : 2017
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-08-STR

SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
NO	ADDRESS	TYPE		***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷	
BRGY. BALIBAGO											
1	#1354 Facundo Compound	D	23-Aug	0.53	-	< 0.02	7.66	-	< 1	ABSENCE	ABSENCE
2	5555 Water Pump Elevated, South Hampton	S	22-Aug	0.88	< 2	< 0.02	7.94	*unobjectionable	< 1	ABSENCE	ABSENCE
3	Clubhouse, South Hampton	D	22-Aug	0.88	-	0.17	7.90	-	< 1	ABSENCE	ABSENCE
4	Block 5 Lot 19, JB Village, Sta. Rosa Tagaytay Road	D	22-Aug	0.83	-	0.06	7.89	-	1	ABSENCE	ABSENCE
5	Cistern Tank, Waltermart Sta. Rosa	D	22-Aug	0.61	-	0.24	8.11	-	4	ABSENCE	ABSENCE
6	2nd Floor Faucet, Waltermart Sta. Rosa	D	22-Aug	0.42	-	< 0.02	8.12	-	1	ABSENCE	ABSENCE
BRGY. CAINGIN											
7	Block 57, Phase 1, Southville	S	15-Aug	0.70	-	< 0.02	8.07	-	< 1	ABSENCE	ABSENCE
8	Block 52 Lot 23, Phase 1, Southville	D	15-Aug	7.94	-	< 0.02	7.94	-	28	ABSENCE	ABSENCE
9	Block 1 Lot 34, Phase 5, Southville	S	15-Aug	< 0.20	-	< 0.02	7.88	-	250	ABSENCE	ABSENCE
10	Block 25 Lot 8, Phase 3, Southville	D	15-Aug	< 0.20	-	< 0.02	7.88	-	9	ABSENCE	ABSENCE
11	Caingin Elementary School	D	15-Aug	0.36	-	0.40	7.91	-	29	ABSENCE	ABSENCE
BRGY. DILA											
12	Phase 3E, Mabuhay Homes 2000	S	7-Aug	< 0.20	-	0.11	7.62	-	-	ABSENCE	ABSENCE
13	Block 2 Lot 10, Mabuhay Homes 2000	D	7-Aug	< 0.20	-	0.08	7.50	-	140	ABSENCE	ABSENCE
14	Block 12, Phase 2E, Mabuhay Homes 2000	S	7-Aug	0.46	-	0.22	7.71	-	-	ABSENCE	ABSENCE
15	Block 13 Lot 5, Phase 2E, Mabuhay Homes 2000	D	7-Aug	0.41	-	0.23	7.68	-	1	ABSENCE	ABSENCE
16	Drinking Fountain, Dila Elementary School	D	10-Aug	< 0.02	-	0.27	7.38	-	-	ABSENCE	ABSENCE
BRGY. DITA											
17	Block 24 Lot 2, New Santa Rosa Homes	S	7-Aug	< 0.20	-	0.06	7.88	-	-	ABSENCE	ABSENCE
18	Block 19 Lot 11, New Santa Rosa Homes	D	7-Aug	< 0.20	-	0.03	7.93	-	49	ABSENCE	ABSENCE
19	Block 4 Lot 32, San Lorenzo Royale	S	7-Aug	0.13	< 2	0.04	7.90	*unobjectionable	-	ABSENCE	ABSENCE
20	Block 11 Lot 52, San Lorenzo Royale	D	7-Aug	0.14	-	< 0.02	7.96	-	8	ABSENCE	ABSENCE
21	Water Tank, SolCar Ville Subdivision	S	7-Aug	0.88	-	< 0.02	7.83	-	-	ABSENCE	ABSENCE
22	Block 3 Lot 7, SolCar Ville Subdivision	D	7-Aug	0.74	-	< 0.02	7.71	-	13	ABSENCE	ABSENCE
24	Alabaster St., Villa Esmeralda	D	7-Aug	0.70	-	1.40	7.80	-	< 1	ABSENCE	ABSENCE
25	#1780 National Road	D	10-Aug	< 0.20	-	< 0.02	7.67	-	-	ABSENCE	ABSENCE

26	R & B Ice Plant, Inc.	D	30-Aug	0.60	-	0.13	7.46	-	27	ABSENCE	ABSENCE
BRGY. DON JOSE											
27	Block 7 Lot 62, Phase 3, Laguna Bel-Air	S	15-Aug	1.03	-	< 0.02	7.41	-	2	ABSENCE	ABSENCE
28	Science HighSchool, Phase 1, Laguna Bel-Air	D	15-Aug	1.21	-	< 0.02	7.38	-	< 1	ABSENCE	ABSENCE
29	Block 34 Lot 14, Phase 1, Laguna Bel-Air	S	15-Aug	0.92	-	< 0.02	7.44	-	2	ABSENCE	ABSENCE
30	Block 34 Lot 59, Phase 1, Laguna Bel-Air	D	15-Aug	0.82	-	< 0.02	7.19	-	< 1	ABSENCE	ABSENCE
31	Clubhouse, Block 62, Laguna Bel-Air	D	15-Aug	0.96	-	< 0.02	7.19	-	27	ABSENCE	ABSENCE
32	Water Pump, Block 71, Phase 4, Laguna Bel-Air	S	15-Aug	0.95	-	0.28	7.39	-	< 1	ABSENCE	ABSENCE
33	Block 71 Lot 4, Phase 2, Laguna Bel-Air	D	15-Aug	0.88	-	< 0.02	7.02	-	46	ABSENCE	ABSENCE
34	Block 108, Phase 5, Laguna Bel-Air	S	15-Aug	0.41	-	< 0.02	7.02	-	< 1	ABSENCE	ABSENCE
35	Church, Block 108, Phase 5, Laguna Bel-Air	D	15-Aug	< 0.20	-	0.34	7.13	-	1	ABSENCE	ABSENCE
36	1NR Block 43, Laguna Bel-Air IV	S	15-Aug	0.70	-	< 0.02	7.22	-	< 1	ABSENCE	ABSENCE
37	Block 47 Lot 12 Laguna Bel-Air IV	D	15-Aug	0.63	-	< 0.02	7.11	-	< 1	ABSENCE	ABSENCE
38	8001, Pump 1, Acacia St., Santa Rosa Village I	S	22-Aug	0.27	-	< 0.02	7.87	-	< 1	ABSENCE	ABSENCE
39	Clubhouse. Phase 4B, Santa Rosa Village I	D	22-Aug	0.22	-	< 0.02	7.61	-	32	ABSENCE	ABSENCE
40	Pump 9 & 10, Rembrandt St., Santa Rosa Estates I	S	22-Aug	0.40	-	< 0.02	8.02	-	2	ABSENCE	ABSENCE
41	Clubhouse, Santa Rosa Village II	D	31-Aug	0.81	-	< 0.02	6.83	-	-	ABSENCE	ABSENCE
42	Clubhouse, Santa Rosa Estates I	D	22-Aug	0.27	-	< 0.02	7.72	-	< 1	ABSENCE	ABSENCE
43	Reservoir, Hacienda Sta. Elena	D	31-Aug	< 0.20	-	0.14	7.39	-	-	ABSENCE	ABSENCE
BRGY. KANLURAN											
44	#621 Rizal Boulevard	D	22-Aug	0.53	-	< 0.02	7.84	-	< 1	ABSENCE	ABSENCE
45	Block 18 Lot 2, Alfonso Homes I	D	15-Aug	0.58	-	< 0.02	8.02	-	310	ABSENCE	ABSENCE
BRGY. MACABLING											
46	Deepwell, Buena Rosa 9 Subdivision	S	8-Aug	1.07	< 2	0.13	7.74	*unobjectionable	-	ABSENCE	ABSENCE
47	Block 11 Lot 9, Phase 2, Buena Rosa 9 Subdivision	D	8-Aug	0.60	-	< 0.02	7.84	-	8	ABSENCE	ABSENCE
48	Deepwell, Corinthian Subdivision	S	8-Aug	1.71	< 2	< 0.02	7.69	*unobjectionable	1	ABSENCE	ABSENCE
49	Block 11 Lot 19, Corinthian Subdivision	D	8-Aug	1.49	-	< 0.02	7.69	-	-	ABSENCE	ABSENCE
50	Deepwell, Rosemont Subdivision	S	8-Aug	1.36	< 2	< 0.02	7.79	*unobjectionable	-	ABSENCE	ABSENCE
51	Block 3 Lot 22, Rosemont Subdivision	D	8-Aug	1.35	-	< 0.02	7.59	-	4	ABSENCE	ABSENCE
52	Water Pump, Metrogate	S	8-Aug	0.48	< 2	< 0.02	7.17	*unobjectionable	-	ABSENCE	ABSENCE
53	Clubhouse, Metrogate	D	8-Aug	1.02	-	< 0.02	7.48	-	< 1	ABSENCE	ABSENCE
BRGY. MALITLIT											
54	Water Pump, Casan Residencia Subdivision	S	30-Aug	0.99	-	1.02	7.15	-	350	ABSENCE	ABSENCE
55	Block 1 Lot 1, Casan Residencia Subdivision	D	30-Aug	0.89	-	0.46	7.29	-	320	ABSENCE	ABSENCE
56	Block 3 Lot 1, Phase 1A Annex, San Lorenzo Subd.	S	7-Aug	0.89	< 2	< 0.02	6.77	*unobjectionable	< 1	ABSENCE	ABSENCE
57	Block 5 Lot 25, Phase 1A Annex, San Lorenzo Subd.	D	7-Aug	0.71	-	< 0.02	7.20	-	-	ABSENCE	ABSENCE
58	Main Road, Phase 2, Terra Fortuna	S	7-Aug	0.14	< 2	0.03	7.84	*unobjectionable	6	ABSENCE	ABSENCE
59	Clubhouse Pantry, Terra Fortuna	D	7-Aug	< 0.20	-	< 0.02	7.88	-	-	ABSENCE	ABSENCE
60	9999 W, Villa Las Casas	S	7-Aug	1.71	< 2	0.46	7.54	*unobjectionable	1	ABSENCE	ABSENCE
61	Block 1 Lot 17, Villa Las Casas	D	7-Aug	1.41	-	0.13	7.30	-	-	ABSENCE	ABSENCE

62	Malitlit Elementary School	D	30-Aug	0.52	-	0.62	6.83	-	23	ABSENCE	ABSENCE
BRGY. MALUSAK											
63	Drinking Fountain 1, Central 1 Elementary Sch.	D	22-Aug	1.17	-	< 0.02	7.69	-	< 1	ABSENCE	ABSENCE
64	Drinking Fountain 2, Central 1 Elementary Sch.	D	22-Aug	1.16	-	0.09	7.84	-	< 1	ABSENCE	ABSENCE
65	Drinking Fountain 3, Central 1 Elementary Sch.	D	22-Aug	1.01	-	< 0.02	7.80	-	< 1	ABSENCE	ABSENCE
BRGY. MARKET AREA											
66	Source, Market Area	S	22-Aug	1.11	< 2	< 0.02	7.82	*unobjectionable	< 1	ABSENCE	ABSENCE
67	Block 9 Lot 2, Terry Town West	D	22-Aug	1.07	-	< 0.02	7.88	-	< 1	ABSENCE	ABSENCE
BRGY. POOC											
68	Deepwell, Alinsod	S	23-Aug	0.70	-	< 0.02	7.62	-	< 1	ABSENCE	ABSENCE
69	Tank, Villa Mercedes	S	15-Aug	1.25	< 2	< 0.02	8.03	*unobjectionable	< 1	ABSENCE	ABSENCE
70	Block 6 Lot 5, Villa Mercedes	D	15-Aug	0.84	-	< 0.02	7.92	-	3	ABSENCE	ABSENCE
BRGY. PULONG SANTA CRUZ											
71	Water Pump, Pulong Sta. Cruz	S	22-Aug	1.27	< 2	< 0.02	7.95	*unobjectionable	< 1	ABSENCE	ABSENCE
72	Block 7 Lot 3 Mercado Village, Pulong Sta. Cruz	D	22-Aug	1.17	-	< 0.02	7.27	-	< 1	ABSENCE	ABSENCE
73	Block 7 Lot 4, Buklod Diwa	D	31-Aug	0.68	-	< 0.02	7.21	-	-	ABSENCE	ABSENCE
BRGY. SINALHAN											
74	Block 6 Lot 10, Bayshore II	D	22-Aug	0.92	-	< 0.02	7.80	-	59	ABSENCE	ABSENCE
75	Block 5 Lot 7, Bayshore I	S	22-Aug	0.43	-	< 0.02	7.85	-	< 1	ABSENCE	ABSENCE
76	4026, Sinalhan Road, Purok 2	S	22-Aug	< 0.20	-	< 0.02	8.03	-	1	ABSENCE	ABSENCE
77	Amoranto Compound, Phase 2, Sinalhan	D	22-Aug	< 0.20	-	< 0.02	7.86	-	71	ABSENCE	ABSENCE
BRGY. SANTO DOMINGO											
78	Clubhouse Santa Rosa Estates II	D	22-Aug	0.35	-	< 0.02	7.80	-	2	ABSENCE	ABSENCE
BRGY. TAGAPO											
79	Water Pump, Fairfield of Margana Subdivision	S	23-Aug	< 0.20	-	< 0.02	7.28	-	-	ABSENCE	ABSENCE
80	Block 1 Lot 18, Fairfield of Margana Subdivision	D	31-Aug	< 0.20	-	0.60	7.28	-	-	ABSENCE	ABSENCE
81	Water Pump, Rosewood Homes I	S	23-Aug	1.08	-	< 0.02	8.00	-	-	ABSENCE	ABSENCE
82	Block 3 Lot 31, Rosewood Homes I	D	23-Aug	0.93	-	< 0.02	7.83	-	-	ABSENCE	ABSENCE
83	Block 4 Lot 1, Rosewood Homes II	D	23-Aug	0.97	-	< 0.02	8.08	-	-	ABSENCE	ABSENCE
84	#31 JP Rizal Boulevard	D	23-Aug	0.23	-	0.08	7.84	-	-	ABSENCE	ABSENCE
85	Water Pump, Buena Rosa 1 Subdivision	S	8-Aug	< 0.20	-	< 0.02	7.50	-	-	ABSENCE	ABSENCE
86	Clubhouse, Buena Rosa 1 Subdivision	D	8-Aug	< 0.20	-	< 0.02	7.71	-	98	ABSENCE	ABSENCE
87	Block 1 Lot 65, Buena Rosa 10 Subdivision	D	23-Aug	0.42	-	0.17	7.93	-	-	ABSENCE	ABSENCE
88	Cistern Tank, SM Sta. Rosa	D	23-Aug	0.49	-	0.28	7.88	-	< 1	ABSENCE	ABSENCE
89	Dakasi, SM Sta. Rosa	D	23-Aug	0.17	-	< 0.02	7.72	-	< 1	ABSENCE	ABSENCE
90	Cistern Tank, Robinson's Mall	D	23-Aug	0.30	-	< 0.02	8.06	-	< 1	ABSENCE	ABSENCE
91	Chummie Shawarma, Robinson's Mall	D	23-Aug	0.32	-	< 0.02	7.96	-	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		91	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:



JOVEN M. MARAVILLA
Analytical Laboratory Head
PRC License No. 0012740

NOTED BY:



CYRIL A. ERICA
Laboratory Services Manager
PRC License No. 0054161

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : CABUYAO	MONTH : AUGUST	YEAR : 2017
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-08-CAB

NO	SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
	ADDRESS	TYPE	***Res. Chlorine ¹ mg/L		Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷		
										TOTAL	<i>Escherichia coli</i>	
BRGY. BANAY-BANAY												
1	Water Pump, Block 63, Lakeside Nest Subdivision	S	10-Aug	0.77	< 2	< 0.02	7.45	**unobjectionable	-	ABSENCE	ABSENCE	
2	Block 12, Lot 5, Phase 4, Lakeside Nest Subdivision	D	10-Aug	1.10	-	0.19	7.66	-	-	ABSENCE	ABSENCE	
BRGY. BANLIC												
3	Water Pump, Gran Seville Subdivision	S	14-Aug	0.25	-	0.18	7.05	-	3	ABSENCE	ABSENCE	
4	Gate Entrance, Gran Seville Subdivision	D	14-Aug	< 0.20	-	< 0.02	7.05	-	-	ABSENCE	ABSENCE	
BRGY. BIGAA												
5	#253 Elsol Subdivision	D	10-Aug	0.75	-	< 0.02	7.74	-	< 1	ABSENCE	ABSENCE	
BRGY. GULOD												
7	Block 12, Noah St., Celestine Ville	S	14-Aug	0.74	< 2	< 0.02	7.60	**unobjectionable	-	ABSENCE	ABSENCE	
8	Guardhouse, Celestine Ville	D	14-Aug	0.58	-	< 0.02	7.67	-	-	ABSENCE	ABSENCE	
BRGY. MAMATID												
9	Tank, Buena Rosario Subdivision	S	14-Aug	< 0.20	-	< 0.02	7.84	-	< 1	ABSENCE	ABSENCE	
10	Block 7 Lot 6, Buena Rosario Subdivision	D	14-Aug	< 0.20	-	< 0.02	7.75	-	-	ABSENCE	ABSENCE	
11	Block 101 Samar st., Phase 2, Mabuhay City	S	14-Aug	0.50	-	< 0.02	7.84	-	-	ABSENCE	ABSENCE	
12	Block 95 Lot 57, Guimaras St., Phase 1, Mabuhay City	D	14-Aug	0.43	-	< 0.02	7.89	-	16	ABSENCE	ABSENCE	
13	Block 141, Carmona St., Phase 2, Mabuhay City	S	14-Aug	0.52	-	< 0.02	7.78	-	-	ABSENCE	ABSENCE	
14	Block 134 Lot 22, Phase 2, Mabuhay City	D	14-Aug	0.42	-	< 0.02	7.83	-	-	ABSENCE	ABSENCE	
15	Block 198, Galacia St., Phase 2, Mabuhay City	S	14-Aug	< 0.20	-	< 0.02	7.64	-	< 1	ABSENCE	ABSENCE	
16	Block 222 Lot 20, Mabuhay Ave, Phase 2, Mabuhay	D	14-Aug	< 0.20	-	< 0.02	7.76	-	< 1	ABSENCE	ABSENCE	
17	Panganig St., Phase 3 Cluster, Mabuhay City	S	14-Aug	0.54	< 2	< 0.02	7.56	*unobjectionable	-	ABSENCE	ABSENCE	
18	Block 1 Lot 17, Dizon St., Phase 3 Cluster, Mabuhay	D	14-Aug	0.58	-	< 0.02	7.70	-	-	ABSENCE	ABSENCE	
19	Block 22 Lot 70, Phase 3 Luxury, Mabuhay City	S	14-Aug	0.46	< 2	< 0.02	7.78	*unobjectionable	-	ABSENCE	ABSENCE	
20	Block 19 Lot 13, Malang St., Phase 3 Luxury,	D	14-Aug	0.45	-	< 0.02	7.78	-	-	ABSENCE	ABSENCE	
21	Joshua St., Phase 5, Mabuhay City	S	10-Aug	0.44	-	< 0.02	7.99	-	-	ABSENCE	ABSENCE	
22	Block 31 Lot 134, Joshua St., Phase 5, Mabuhay City	D	10-Aug	0.51	-	< 0.02	7.98	-	-	ABSENCE	ABSENCE	

23	Source, Phase 1E Mabuhay Executive	S	14-Aug	0.69	< 2	< 0.02	7.88	*unobjectionable	41	ABSENCE	ABSENCE	
24	Block 236 Lot 9, Phase 1E Mabuhay Executive	D	14-Aug	0.45	-	< 0.02	7.86	-	-	ABSENCE	ABSENCE	
BRGY. MARINIG												
25	Block 3 Lot 17, Phase 1, Celestine Homes	S	10-Aug	0.85	< 2	< 0.02	8.02	**unobjectionable	-	ABSENCE	ABSENCE	
26	Block 23, Lot 10, Phase 1, Celestine Homes	D	10-Aug	0.90	-	< 0.02	7.84	-	-	ABSENCE	ABSENCE	
27	Block 9, Carnation St., Phase 2, Celestine Homes	S	10-Aug	1.37	< 2	< 0.02	8.00	**unobjectionable	11	ABSENCE	ABSENCE	
28	Block 13 Lot 2, Phase 2, Celestine Homes	D	10-Aug	1.05	-	< 0.02	7.79	-	-	ABSENCE	ABSENCE	
29	Block 25, Phase 3, Southville	S	10-Aug	0.71	< 2	< 0.02	7.75	**unobjectionable	< 1	ABSENCE	ABSENCE	
30	Block 19 Lot 33, Phase 3, Southville	D	10-Aug	0.70	-	< 0.02	7.83	-	-	ABSENCE	ABSENCE	
BRGY. NIUGAN												
32	Block 2 Lot 6, St. Francis Homes 6	D	14-Aug	0.38	-	< 0.02	7.78	-	-	ABSENCE	ABSENCE	
33	Block 45, Phase 8, Southville	S	14-Aug	0.70	< 2	< 0.02	7.71	**unobjectionable	-	ABSENCE	ABSENCE	
34	Block 40 Lot 132, Southville	D	14-Aug	0.77	-	< 0.02	7.72	-	-	ABSENCE	ABSENCE	
35	Block 54, Phase 10, Southville	S	14-Aug	0.61	< 2	< 0.02	7.61	*unobjectionable	7	ABSENCE	ABSENCE	
36	Block 47 Lot 101, Phase 10, Southville	D	14-Aug	0.59	-	< 0.02	7.76	-	-	ABSENCE	ABSENCE	
BRGY. PULO												
37	Water Pump, Block 12 Lot 22, Cabuyao Central	S	10-Aug	0.33	-	0.17	816	-	-	ABSENCE	ABSENCE	
38	Clubhouse, Narra Avenue, Cabuyao Central	D	10-Aug	0.74	-	1.78	7.71	-	-	ABSENCE	ABSENCE	
39	Water Pump, Block 11, Willow Park Homes	S	10-Aug	1.05	< 2	< 0.02	7.86	**unobjectionable	-	ABSENCE	ABSENCE	
40	Clubhouse, Willow Park Homes	D	10-Aug	0.90	-	< 0.02	7.86	-	-	ABSENCE	ABSENCE	
BRGY. SALA												
41	Gate Entrance, Main St., Multiland III	D	10-Aug	0.21	-	< 0.02	7.86	-	< 1	ABSENCE	ABSENCE	
BRGY. SAN ISIDRO												
42	Source, Multiland IV	S	10-Aug	< 0.20	-	0.38	7.21	-	5	ABSENCE	ABSENCE	
43	Block 3 Lot 33, Multiland IV	D	10-Aug	< 0.20	-	0.20	7.22	-	-	ABSENCE	ABSENCE	
44	Water Pump, San Isidro Heights Subdivision	S	10-Aug	0.36	-	< 0.02	7.16	-	< 1	ABSENCE	ABSENCE	
45	Block 3 Lot 1, San Isidro Heights Subdivision	D	10-Aug	0.12	-	< 0.02	7.44	-	-	ABSENCE	ABSENCE	
TOTAL SAMPLES ANALYZED			45	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE

REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:



JOVEN M. MARAVILLA
Analytical Laboratory Head
PRC License No. 0012740

NOTED BY:



CYRIL A. ERICA
Laboratory Services Manager
PRC License No. 0054161

Page 2 of 2

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

Laguna AAWater Corporation | G/F One Evotech Bldg., Nuvali, Sta. Rosa City, Laguna | +63 49 544-4386 • +63 2 519-4429 | www.lagunawater.com.ph

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : CALAMBA	MONTH : AUGUST	YEAR : 2017
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-08-CAL

SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
NO	ADDRESS	TYPE		***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷ TOTAL	<i>Escherichia coli</i>
BRGY. BARANDAL											
1	Deepwell 1, Amaia Scapes Calamba	S	24-Aug	0.72	-	< 0.02	7.82	-	-	ABSENCE	ABSENCE
2	Block 1 Lot 2, Amaia Scapes Calamba	D	24-Aug	0.67	-	< 0.02	7.54	-	< 1	ABSENCE	ABSENCE
3	Deepwell 2, Amaia Scapes Calamba	S	24-Aug	0.62	-	< 0.02	7.74	-	-	ABSENCE	ABSENCE
4	Block 39 Lot 5, Amaia Scapes Calamba	D	24-Aug	0.51	-	< 0.02	7.62	-	3	ABSENCE	ABSENCE
BRGY. PUTING LUPA											
5	Phase 1, Greenfields	D	24-Aug	0.71	-	0.11	7.47	-	-	ABSENCE	ABSENCE
6	Block 11, Kanlaon St., Greenfields	D	24-Aug	0.79	-	< 0.02	7.79	-	< 1	ABSENCE	ABSENCE
7	Clubhouse, Greenfields	D	24-Aug	0.51	-	0.14	7.60	-	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED			7	PNSDW LIMIT 0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE


REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution


DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:


JOVEN M. MARAVILLA
Analytical Laboratory Head
PRC License No. 0012740

NOTED BY:


CYRIL A. ERICA
Laboratory Services Manager
PRC License No. 0054161

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : ALAMINOS	MONTH : AUGUST	YEAR : 2017
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-08-ALA

SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
NO	ADDRESS	TYPE		***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷ TOTAL	<i>Escherichia coli</i>
BRGY. SAN ANDRES											
1	Water Tank, Bellavita Homes	S	24-Aug	0.34	< 2	< 0.02	7.67	*unobjectionable	-	ABSENCE	ABSENCE
2	CLubhouse, BellaVita Homes	D	24-Aug	0.37	-	< 0.02	7.36	-	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE


REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:



JOVEN M. MARAVILLA
Analytical Laboratory Head
PRC License No. 0012740

NOTED BY:



CYRIL A. ERICA
Laboratory Services Manager
PRC License No. 0054161

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : SANTA CRUZ	MONTH : AUGUST	YEAR : 2017
DOH ACCREDIATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-08-STC

SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
NO	ADDRESS	TYPE		***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷	
									TOTAL	Escherichia coli	
BRGY. BUBUKAL											
1	Source after Filter, Laguna Sports Complex	S	30-Aug	0.88	< 2	< 0.02	8.37	**unobjectionable	-	ABSENCE	ABSENCE
2	Canteen No. 4 in front of Laguna University	D	30-Aug	1.03	-	0.28	8.04	-	-	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE


REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2 ACU, Turbidity = 0.02 NTU


METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:



JOVEN M. MARAVILLA
Analytical Laboratory Head
PRC License No. 0012740

NOTED BY:



CYRIL A. ERICA
Laboratory Services Manager
PRC License No. 0054161

LAGUNA AAAWATER CORPORATION
OPERATIONS DEPARTMENT
LABORATORY SERVICES
SAMPLES FROM SOURCE AND CONSUMER'S TAPS - PROVINCE OF LAGUNA

CITY/MUNICIPALITY : PAGSANJAN	MONTH : AUGUST	YEAR : 2017
DOH ACCREDITATION NO : 04A-010-16-LW-2	VALIDITY : December 31, 2018	DOCUMENT NO : 17WQM-08-PAG

SAMPLE LOCATION			DATE COLLECTED	PHYSICAL/CHEMICAL QUALITY					MICROBIOLOGICAL QUALITY		
NO	ADDRESS	TYPE		***Res. Chlorine ¹ mg/L	Color ² ACU	Turbidity ³ NTU	pH ⁴	Taste/Odor ⁵	HPC ⁶ CFU/mL	Coliforms/100 mL ⁷ TOTAL	Escherichia coli
BRGY. SABANG											
1	Purok 6, Moresco Ville 2	S	30-Aug	0.52	< 2	0.38	7.8	*unobjectionable	-	ABSENCE	ABSENCE
2	Reservoir, Moresco Ville 2	S	30-Aug	0.29	-	1.47	7.71	-	< 1	ABSENCE	ABSENCE
TOTAL SAMPLES ANALYZED		2	PNSDW LIMIT	0.30 - 1.50	10 (max)	5 (max)	6.5 - 8.5	unobjectionable	<500	ABSENCE	ABSENCE


REMARKS: Samples analyzed as submitted

LEGEND: ACU - Apparent Color Unit, NTU -Nephelometric Turbidity Unit, HPC - Heterotrophic Plate Count, ***-onsite testing, * - unobjectionable - slightly chlorinous, ** - unobjectionable - chlorinous, S - Source, D - Distribution

DETECTION LIMIT: Residual Chlorine = 0.20 mg/L, Color = 2 ACU, Turbidity = 0.02 NTU

METHODS USED: ¹DPD Colorimetric, ²Visual Comparison-Platinum/Cobalt, ³Nephelometric, ⁴Electrometric, ⁵Sensory, ⁶Pour Plate, ⁷Enzyme Substrate (Colilert®-18)

CERTIFIED CORRECT:



JOVEN M. MARAVILLA
Analytical Laboratory Head
PRC License No. 0012740

NOTED BY:



CYRIL A. ERCA
Laboratory Services Manager
PRC License No. 0054161