

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna
CONTACT NO.: (049) 543-1916
WEBSITE: www.lagunawater.com.ph

CUSTOMER NAME : LAGUNA AAAWATER CORPORATION

ADDRESS : G/F One Evotech Building, Lakeside Evozone, Nuvali, Brgy. Santo Domingo, Santa Rosa City, Laguna

ATTENTION : BIÑAN CITY HEALTH OFFICE

SUMMARY OF LABORATORY ANALYSIS

NO. OF SAMPLES : 78

TOTAL PARAMETERS TESTED : 5

ANALYSIS DATE(S) : 08/02/2021 – 08/31/2021

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. BIÑAN							
08/12/2021 12:29	S21-5793	Laguna Wellfield 1	7.12 / 27.5	0.42	ABSENCE	ABSENCE	< 1
08/03/2021 15:41	S21-5549	Guardhouse Entrance, Phase 4C, San Jose Village I	7.61 / 28.6	0.36	ABSENCE	ABSENCE	< 1
08/03/2021 15:36	S21-5550	Clubhouse, Phase 3B, San Jose Village II	7.49 / 27.6	0.34	ABSENCE	ABSENCE	< 1
08/03/2021 14:35	S21-5551	Pump 11, Phase 5, San Jose Village II	7.41 / 27.7	0.38	ABSENCE	ABSENCE	< 1
08/03/2021 15:10	S21-5552	Clubhouse, Phase 5, San Jose Village II	7.60 / 27.5	0.40	ABSENCE	ABSENCE	< 1
08/03/2021 15:16	S21-5553	Clubhouse, Phase 6, San Jose Village III	7.51 / 28.8	0.38	ABSENCE	ABSENCE	< 1
08/03/2021 15:24	S21-5554	Main Gate, AVIDA Shophouse	7.60 / 27.5	0.55	ABSENCE	ABSENCE	< 1
08/03/2021 14:16	S21-5555	DLSU Science and Technology Complex, LTI Spine Road	7.53 / 28.6	0.51	ABSENCE	ABSENCE	< 1
BRGY. CANLALAY							
08/02/2021 13:48	S21-5494	Clubhouse, Golden City Subdivision	7.29 / 30.7	0.28	ABSENCE	ABSENCE	11
08/02/2021 14:03	S21-5495	Drinking Fountain, Canlalay Elementary School	7.24 / 30.4	0.27	ABSENCE	ABSENCE	< 1
BRGY. DELA PAZ							
08/02/2021 13:19	S21-5500	Water Pump, Almeda Subdivision	7.62 / 29.7	0.07	ABSENCE	ABSENCE	10
BRGY. GANADO							
08/02/2021 14:48	S21-5459	Ganado Elementary School	7.51 / 29.3	0.32	ABSENCE	ABSENCE	< 1
BRGY. HALANG							
08/02/2021 14:18	S21-5490	9999 Water Pump Metroville Complex	7.16 / 29.5	0.40	ABSENCE	ABSENCE	< 1
08/02/2021 14:28	S21-5491	Clubhouse, Metroville Complex	7.18 / 29.5	0.24	ABSENCE	ABSENCE	< 1
BRGY. LANGKIWA							
08/03/2021 11:12	S21-5538	Block 3 Lot 9, Phase II, Southville	7.55 / 29.6	0.30	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916


WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20	TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
08/03/2021 13:10	S21-5559	Drinking Fountain, Southville 5A National High School	7.50 / 29.0	0.25	ABSENCE	ABSENCE	< 1
08/03/2021 12:49	S21-5560	Drinking Fountain, Langkiwa Elementary School	7.48 / 27.7	0.36	ABSENCE	ABSENCE	< 1
BRGY. LOMA							
08/03/2021 13:59	S21-5556	Block 43 Lot 13, Celina Technopark	7.40 / 27.6	0.35	ABSENCE	ABSENCE	< 1
08/19/2021 12:59	S21-6085	Brenna Model House, Laguna Bel-Air III	7.47 / 30.3	0.28	ABSENCE	ABSENCE	< 1
08/19/2021 13:14	S21-6086	Hillcrest Road, Block 2 Laguna Bel-Air III	7.47 / 29.8	0.25	ABSENCE	ABSENCE	< 1
08/19/2021 13:03	S21-6087	Clubhouse, Laguna Bel-Air III	7.50 / 30.1	0.23	ABSENCE	ABSENCE	< 1
08/03/2021 13:22	S21-5558	Drinking Fountain, Loma Elementary	7.38 / 27.5	0.38	ABSENCE	ABSENCE	< 1
BRGY. MAMPLASAN							
08/03/2021 13:44	S21-5557	Clubhouse, Verdana Homes Subdivision	7.42 / 28.5	0.41	ABSENCE	ABSENCE	< 1
08/02/2021 15:09	S21-5460	United Laboratories (UNILAB) Inc.	7.55 / 30.1	0.30	ABSENCE	ABSENCE	< 1
BRGY. POBLACION							
08/02/2021 13:02	S21-5501	Barangay Hall	7.29 / 30.1	0.05	ABSENCE	ABSENCE	< 1
BRGY. PLATERO							
08/05/2021 11:10	S21-5611	Elevated Water Tank, Mondo Bambini	7.60 / 27.5	0.44	ABSENCE	ABSENCE	-
08/05/2021 11:30	S21-5612	Clubhouse, Mondo Bambini	7.46 / 28.5	0.36	ABSENCE	ABSENCE	-
08/05/2021 13:30	S21-5613	Elevated Water Tank, Prima Casa	7.70 / 27.6	0.29	ABSENCE	ABSENCE	-
08/05/2021 13:16	S21-5614	Clubhouse, Prima Casa	7.68 / 27.5	0.20	ABSENCE	ABSENCE	-
08/05/2021 12:56	S21-5215	Water Pump, Spring Time	7.41 / 29.0	0.34	ABSENCE	ABSENCE	-
08/05/2021 13:10	S21-5216	Block 1 Lot 7, Spring Time	7.52 / 28.5	0.26	ABSENCE	ABSENCE	-
08/02/2021 13:39	S21-5462	Sea-oil, National Road	7.61 / 30.1	0.37	ABSENCE	ABSENCE	< 1
08/02/2021 13:18	S21-5464	Drinking Fountain, St. Michael School	7.55 / 30.7	0.10	ABSENCE	ABSENCE	< 1
08/05/2021 14:53	S21-5217	Tank 2, Jubilation Village - West	7.60 / 29.0	0.08	ABSENCE	ABSENCE	-
08/05/2021 15:10	S21-5218	Clubhouse, Jubilation Village - West	7.45 / 28.7	0.06	ABSENCE	ABSENCE	-
08/05/2021 14:26	S21-5221	Water Pump, Jubilation Village - East	7.68 / 27.8	0.12	ABSENCE	ABSENCE	-
08/05/2021 14:44	S21-5222	Clubhouse, Jubilation Village - East	7.85 / 27.5	0.08	ABSENCE	ABSENCE	-


NOT VALID WITHOUT QR CODE



REVIEWED BY:


ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:


ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
			MDL: NA LOQ: NA	MDL: 0.06 LOQ: 0.20			
BRGY. SAN ANTONIO							
08/02/2021 11:16	S21-5470	Water Pump, Biñan City Hall	7.60 / 30.3	0.65	ABSENCE	ABSENCE	< 1
08/02/2021 11:33	S21-5471	Alonte Stadium	7.65 / 30.7	0.62	ABSENCE	ABSENCE	< 1
08/02/2021 12:17	S21-5465	Water Pump, Margarita Homes Subdivision	7.47 / 30.8	0.36	ABSENCE	ABSENCE	< 1
08/02/2021 12:38	S21-5466	Ibanez Residence, Margarita Homes	7.52 / 30.6	0.33	ABSENCE	ABSENCE	< 1
08/02/2021 16:07	S21-5496	9022 Water Pump, Faraon Subdivision	7.64 / 30.5	0.16	ABSENCE	ABSENCE	< 1
08/02/2021 12:12	S21-5502	Drinking Fountain, Jacobo Z Gonzales Memorial National High School	7.35 / 29.0	0.40	ABSENCE	ABSENCE	< 1
08/02/2021 14:09	S21-5467	Cistern Tank, Pavilion Mall	7.51 / 30.3	0.28	ABSENCE	ABSENCE	< 1
08/02/2021 14:20	S21-5468	Pan de Manila, Pavilion Mall	7.51 / 30.7	0.25	ABSENCE	ABSENCE	< 1
08/02/2021 15:46	S21-5497	Malaban Health Center	7.56 / 31.1	0.25	ABSENCE	ABSENCE	< 1
08/02/2021 15:30	S21-5498	Drinking Fountain 1, Malaban Elementary School	7.55 / 33.9	0.15	ABSENCE	ABSENCE	30
08/02/2021 15:36	S21-5499	Hand Wash Area, Malaban Elementary School	7.54 / 31.0	0.28	ABSENCE	ABSENCE	2
BRGY. SANTO NIÑO							
08/02/2021 11:59	S21-5469	Jollibee National Hi-Way	7.66 / 30.1	0.30	ABSENCE	ABSENCE	< 1
BRGY. SAN VICENTE							
08/02/2021 10:50	S21-5472	407 Water Pump, San Vicente Subdivision	7.62 / 30.3	0.23	ABSENCE	ABSENCE	< 1
08/03/2021 10:35	S21-5539	Drinking Fountain, San Vicente Elementary School	7.47 / 30.1	0.17	ABSENCE	ABSENCE	< 1
08/03/2021 10:56	S21-5540	Block 12 Lot 5, Papaya St., Phase 7 Olivarez Homes	7.52 / 30.7	0.22	ABSENCE	ABSENCE	< 1
08/03/2021 13:44	S21-5541	Cistern Tank, Central Mall	7.41 / 29.7	0.29	ABSENCE	ABSENCE	< 1
08/02/2021 12:57	S21-5463	Biñan Doctor's Hospital	7.65 / 30.4	0.25	ABSENCE	ABSENCE	< 1
BRGY. SANTO TOMAS							
08/02/2021 10:13	S21-5461	Water Pump, Adelina Complex 3	7.51 / 29.7	0.42	ABSENCE	ABSENCE	< 1
08/02/2021 10:30	S21-5473	HOA Office, Adelina Complex	7.50 / 30.1	0.33	ABSENCE	ABSENCE	< 1
08/03/2021 12:38	S21-5547	Water Pump, Pragmatic Subdivision	7.61 / 29.8	0.15	ABSENCE	ABSENCE	< 1
08/03/2021 12:52	S21-5548	Reyes Compound, Bais St., Pragmatic	7.51 / 30.1	0.10	ABSENCE	ABSENCE	< 1
08/03/2021 11:58	S21-5536	Tawi Tawi St., Phase 6, South City Homes	7.65 / 30.1	0.24	ABSENCE	ABSENCE	2
08/03/2021 12:08	S21-5534	Water Pump, South Plains II Subdivision	7.61 / 29.7	0.30	ABSENCE	ABSENCE	< 1
08/03/2021 12:16	S21-5535	Block 11 Lot 2, South Plains II Subdivision	7.60 / 30.1	0.21	ABSENCE	ABSENCE	< 1

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.

ADDRESS: 8 North Science Avenue, Laguna Technopark Inc., Brgy. Biñan (Poblacion), Biñan City, Laguna

CONTACT NO.: (049) 543-1916

WEBSITE: www.lagunawater.com.ph

DATE/TIME COLLECTED	SAMPLE CODE	SAMPLE LOCATION	PARAMETER				
			pH/ Temperature ^A (- / °C)	RESIDUAL CHLORINE ^B (mg/L)	COLIFORM ^C		HPC ^D (CFU/mL)
					TOTAL (Coliforms/ 100mL)	FECAL/ <i>E. coli</i> (Coliforms/ 100 mL)	
08/03/2021 10:07	S21-5542	Water Pump, Town & Country, Amsterdam	7.60 / 30.7	0.35	ABSENCE	ABSENCE	< 1
08/03/2021 10:12	S21-5543	Blk 35 Lot 21, Southville Town & Country	7.55 / 30.7	0.33	ABSENCE	ABSENCE	< 1
08/03/2021 09:50	S21-5544	Blk 2 Lot 5, Town & Country, Pennsylvania	7.55 / 29.8	0.32	ABSENCE	ABSENCE	< 1
08/03/2021 13:08	S21-5545	Water Pump, Phase 4, Olivarez Homes South	7.47 / 29.6	0.33	ABSENCE	ABSENCE	< 1
08/03/2021 13:17	S21-5546	Blk 1 Lt 16, Phase 4, Olivarez Homes South	7.41 / 30.7	0.27	ABSENCE	ABSENCE	< 1
BRGY. SORO – SORO							
08/02/2021 14:55	S21-5492	Water Pump, 9067 Manila S Road	7.17 / 29.4	0.74	ABSENCE	ABSENCE	< 1
08/02/2021 14:47	S21-5493	#76 Manila S Road	7.18 / 30.2	0.68	ABSENCE	ABSENCE	< 1
BRGY. TIMBAO							
08/03/2021 12:21	S21-5561	Water Pump, San Antonio South	7.68 / 27.6	0.31	ABSENCE	ABSENCE	< 1
08/03/2021 12:36	S21-5562	Block 3 Lot 23, San Antonio South	7.70 / 28.2	0.28	ABSENCE	ABSENCE	< 1
BRGY. TUBIGAN							
08/03/2021 11:37	S21-5537	#60 Florinda Compound	7.62 / 30.7	0.18	ABSENCE	ABSENCE	< 1
BRGY. ZAPOTE							
08/05/2021 10:30	S21-5607	Water Pump, Summer Breeze	7.38 / 27.5	0.38	ABSENCE	ABSENCE	-
08/05/2021 10:38	S21-5608	Clubhouse, Summer Breeze	7.40 / 28.5	0.46	ABSENCE	ABSENCE	-
08/05/2021 12:08	S21-5609	Elevated Water Tank, Evergreen	7.55 / 28.9	0.55	ABSENCE	ABSENCE	-
08/05/2021 12:23	S21-5610	Clubhouse, Evergreen	7.48 / 28.7	0.49	ABSENCE	ABSENCE	-
08/05/2021 15:28	S21-5219	Water Pump, Jubilation Village - South	7.68 / 29.0	0.12	ABSENCE	ABSENCE	-
08/05/2021 15:39	S21-5220	Clubhouse, Jubilation Village - South	7.63 / 27.5	0.17	ABSENCE	ABSENCE	-
08/31/2021 13:31	S21-6212	Clubhouse, Althea Residences	-	0.16	ABSENCE	ABSENCE	-

REMARKS: Sample collection was performed by LWC Field analyst/Laboratory technicians and were analyzed as submitted.

LEGEND: **HPC** – Heterotrophic Plate Count; **CFU** – Colony Forming Units; **MDL** – Method Detection Limit; **LOQ** – Limit of Quantification; **NA** – Not Applicable

DEVIATIONS: No deviation noted on sample collection and submission.

METHODS: **A** – Electrometric; **B** – Colorimetric; **C** – Enzyme Substrate; **D** – Pour Plate

METHOD REFERENCE: Standard Methods for the Examination of Water and Wastewater, 23rd Edition

NOT VALID WITHOUT QR CODE



REVIEWED BY:

ALYSSA MARIE C. PENALES, RMT
Microbiology Unit Manager (OIC)
License No(s). (PRC 0064969)

CERTIFIED CORRECT BY:

ANNA KARLA S. GUTIERREZ, RMT
Laboratory Services Manager
License No(s). (PRC 0060968)

This report may not be reproduced in part or in full and may not be used for advertisement or litigation purposes without permission from Laguna AAWater Corporation. This report is certified to have passed the Laguna AAWater Corporation Quality Control procedures for reporting results of analysis.